

CUSTOMER SERVICE POLICIES

CUSTOMER SERVICE POLICIES	1
1.0 PREAMBLE.....	1
1.1 DEFINITION OF TERMS	2
2.0 GENERAL POLICIES	7
2.1.1 Metering Point.....	7
2.1.2 Determination of Applicability.....	7
2.2 RATE SCHEDULES.....	7
2.2.1 Rate Schedule Exceptions	7
2.3 NEW LOADS.....	8
2.4 EXCLUSIVE SOURCE AND RESALE	8
2.5 GRANT PUD'S OBLIGATIONS.....	8
2.5.1 Limitations of Damages.....	8
2.6 CUSTOMER'S OBLIGATIONS	9
2.6.1 Increased Load	9
2.6.2 Balancing of Load	9
2.6.3 Total Harmonic Distortion (THD).....	9
2.6.4 Surge Protection	9
2.7 APPLICATION FOR SERVICE	9
2.8 DISCONNECTING SERVICES.....	10
2.9 LIFE SUPPORT SYSTEMS	11
2.9.1 Customer Obligations.....	11
2.10 DAMAGE TO GRANT PUD FACILITIES	11
2.11 DISCLOSURE OF PUBLIC RECORDS.....	11
2.12 SERVICE OUTSIDE GRANT COUNTY.....	11
2.13 UNDERGROUND FACILITIES	11
2.14 REVENUE PROTECTION AND POWER DIVERSION	12
2.15 INFORMAL CONFERENCE / HEARINGS.....	13
3.0 CONSERVATION	14
3.1 DEMAND RESPONSE.....	14
3.2 RESIDENTIAL, COMMERCIAL, INDUSTRIAL AND IRRIGATION ASSISTANCE.....	14
4.0 LINE EXTENSION POLICY FOR CUSTOMER SERVICES UNDER 500 KW	15
4.1 OVERHEAD LINE EXTENSIONS	15
4.2 UNDERGROUND LINE EXTENSIONS	15
4.3 TYPES OF SERVICE.....	16
4.3.1 Permanent Service.....	16
4.3.2 Non-Permanent Service.....	16
4.3.3 Construction Temporary Service.....	16
4.4 SERVICE REQUIREMENTS BY RATE CLASS	16
4.5 CALCULATION OF CHARGES	17

4.5.1	Line Extension Fees.....	17
4.5.2	Line Extension Fee Payments	18
4.6	MODIFICATION OF FACILITIES	18
4.7	REBUILDING EXISTING LINES	19
4.8	TRANSMISSION FACILITIES.....	19
4.9	SUBSTATIONS.....	19
4.10	DISTRIBUTION POWER LINES.....	19
4.10.1	Area Feeder Lines.....	19
4.10.2	Distribution Power Lines That Are Not Area Feeders	19
4.11	EXTENSIONS TO RESIDENTIAL/COMMERCIAL SUBDIVISIONS.....	20
4.11.1	Approved Subdivisions.....	20
4.11.2	Services within a Subdivision.....	20
4.12	MANUFACTURED HOME / MOBILE HOME PARKS.....	20
4.13	UNUSED IRRIGATION SERVICE FACILITIES	21
5.0	SERVICE AND METER REGULATIONS.....	22
5.1.1	Determination of Availability.....	22
5.1.2	Compliance with Regulations and Codes	22
5.1.3	Access to and Care of Grant PUD Property.....	22
5.1.4	Customer Responsibility	22
5.1.5	Separate Services.....	22
5.1.6	Backup and Maintenance Power	23
5.1.7	Station Service - Customer Owned.....	23
5.2	SERVICE LATERAL AND POINT OF CONNECTION.....	23
5.2.1	Overhead Service Laterals.....	23
5.2.2	Underground Service Laterals	23
5.3	SERVICE ENTRANCE INSTALLATION AND EQUIPMENT	24
5.3.1	Responsibility of Customer/Grant PUD.....	24
5.3.2	Wiring.....	24
5.3.3	Protective Devices	24
5.3.4	Protective Equipment on Motor Installations.....	24
5.3.5	Service Connection.....	24
5.4	METER LOCATIONS.....	24
5.4.1	Placement of Meters	24
5.4.2	Meter Height Requirements	25
5.4.3	Line Side/Load Side Placement of Equipment.....	25
5.4.4	Conditions Adversely Affecting Meters	25
5.4.5	New Installation - Instrument Transformers	26
5.4.6	Placement of Meter Bases	26
5.4.7	Meter Violation	26
5.5	METERING EQUIPMENT.....	26
5.5.1	Standards for Metering Equipment	26

5.5.2	Power Factor Metering	26
5.5.3	Pulse Metering Data Connection	26
5.6	INTERCONNECTION OF CUSTOMER-OWNED NET METERING SYSTEMS	27
5.6.1	Application, Fees and Agreement	27
5.6.2	Certification of Completion	27
5.6.3	Unauthorized Connections	27
5.6.4	Metering	27
5.6.5	Future Modification or Expansion.....	27
5.6.6	Grant PUD System Capacity.....	28
5.6.7	Customer Owned Protection	28
5.6.8	Interconnection Costs	28
6.0	METER READING, BILLING AND COLLECTING	29
6.1	METER READING	29
6.2	ADJUSTMENT OF BILLING ERRORS.....	29
6.3	BILLING PERIODS	29
6.4	NON-METERED SERVICE.....	29
6.5	DETERMINATION OF DEMAND	29
6.6	PAYMENT	30
6.7	RETURN CHECK FEE.....	30
6.8	PAYMENT OPTIONS.....	30
6.9	BUDGETPAY	30
6.10	LATE PAYMENT CHARGES	30
6.11	ACCOUNT SERVICE CHARGE	30
6.12	AFTER-HOURS FEE	30
6.13	DEPOSITS.....	30
6.13.1	Current Credit Rating	31
6.13.2	Interest on Deposits	31
6.14	NEW OR ADDITIONAL DEPOSIT REQUIREMENTS	31
6.15	TERMINATION OF SERVICE.....	31
6.16	DELINQUENCY-DISCONTINUANCE OF SERVICE.....	31
6.16.1	Right to Disconnect.....	31
6.16.2	Due Process	32
6.17	DISCONNECT FOR NON-PAYMENT	32
6.17.1	Disconnect Fee	32
6.17.2	Moratorium.....	32
6.18	LANDLORD/TENANT ARRANGEMENTS.....	32
6.19	ELIGIBILITY FOR SPECIAL LOW INCOME RATE DISCOUNTS.....	32
6.20	NET METERING BILLING	33
6.21	RENEWABLE ENERGY SYSTEM COST RECOVERY	34
7.0	STREET LIGHTING SERVICE	35
7.1	AVAILABILITY.....	35

7.2	SPECIFICATIONS	35
7.3	LINE EXTENSION POLICY - STREET LIGHTS	35
7.3.1	Underground Service to Street Lights	35
7.4	TERMINATION OF SERVICE	35
7.5	CONTINUITY OF SERVICE	35
8.0	LARGE POWER CUSTOMER ELECTRIC SERVICE ABOVE 500 KW/KVA	37
8.1	NEW LARGE ELECTRIC SERVICE	37
8.2	CUSTOMER RESPONSIBILITIES.....	37
8.3	FACILITIES	38
8.4	CUSTOMER CONTRIBUTION FOR CONNECTION	38
8.5	REDUNDANT FACILITIES	38
8.5.1	Redundant Distribution.....	38
8.5.2	Redundant Transformer	38
8.5.3	Redundant Transmission	39
9.0	EVOLVING INDUSTRY	40
9.1	RISK CONSIDERATIONS FOR INCLUSION	40
9.1.1	Concentration Risk.....	40
9.1.2	Business Risk.....	40
9.1.3	Regulatory Risk.....	40
9.2	PERIODIC REVIEW BY ASSESSMENT TEAM	40
9.3	INCLUSION IN THE EVOLVING INDUSTRY RATE CLASS.....	40
9.4	RATE 17 DESIGN.....	41
9.5	COMMISSION REPORTING	41
9.6	APPLICATION AND QUEUE	41
9.7	ATTESTATIONS	41
9.8	LOAD SPLITTING AND METERING	41
9.9	DETECTION AND ENFORCEMENT	42
9.10	PENALTIES	42
9.11	INFORMAL CONFERENCE / HEARINGS.....	42
10.0	REVISIONS.....	43

CUSTOMER SERVICE POLICIES

PUBLIC UTILITY DISTRICT NO. 2 OF GRANT COUNTY, WASHINGTON

1.0 PREAMBLE

These Customer Service Policies (“CSP”s) have been adopted by Public Utility District No. 2 of Grant County, Washington (“District” or “Grant PUD”) in accordance with Grant PUD’s mission, vision and values. The CSP is subject to revision by Grant PUD Board of Commissioners (Commission) at any time to meet these objectives. These policies are to serve as a guide to the employees of Grant PUD to provide the best possible service to our customers using uniform and equitable consideration. Construction details and specifications will conform to current state and national regulations governing such matters and are intended to comply with any state, regional, and local statutes. The CSP shall be considered to be amended whenever a law, regulation, statute, ordinance or equivalent changes so as to comply with such change until the CSP is updated.

Grant PUD reserves the right to disconnect the supply of electric energy, capacity, and ancillary services in the event the Customer fails to comply with any policies, provisions or any agreement the Customer has with Grant PUD. Service may be disconnected by Grant PUD at any time to prevent fraudulent use or to protect its property.

Grant PUD encourages and invites public input regarding Grant PUD Rate Schedules and policies. Grant PUD will make reasonable efforts to notify the public of changes to the CSP. Such notification may include press releases, public announcements, notices with Customer billings, or posts on Grant PUD’s website. Agenda information and commission meeting schedules can be found at grantpud.org.

1.1 DEFINITION OF TERMS

The following terms shall have the meanings as defined below:

Term	Definition
Account	The physical premises and Meter or Metering Point record plus the measurement, billing and payment information and other data associated with the Electric Service provided to the Customer at the Premises.
Area Feeder	A primary distribution circuit constructed to provide for general area load growth and system reliability, the cost of which is borne entirely by Grant PUD and included in Grant PUD's rate base. (See Section 4.10.1)
Backbone Facilities	Those facilities within a subdivision required to provide Electric Power to the property line of each lot or tract. Said facilities include transformers when multiple lots or tracts are to be served from a single transformer and the location of transformers can be established at the time Backbone Facilities are installed.
Billing Demand	The billing determinant for capacity that uses the highest kW demand after adjusting for Power Factors below 95%. Can be based on the metered kWh, computed, or fixed monthly amount.
Billing Determinant	The unit used to calculate a bill such as kilowatt-hours.
Connection Point	The designated point on the Customer's property where their secondary service is connected to Grant PUD's facilities. This would be at the weatherhead for an overhead service and at a secondary termination point (moped(pedestal)/vault/transformer) for an underground service.
Construction Temporary Service	A temporary service providing power to a construction site for a limited period of time.
Construction Temporary Service Fee	The fee paid for a Construction Temporary Service for a limited period of time.
Customer	Any individual, group, partnership, corporation, firm or government agency who has applied for or is accepting Electric and Fiber services from Grant PUD.
Customer Contribution	An amount paid by a Customer that is adding incremental load to Grant PUD's Electric System which reduces or eliminates the shifting of long-term costs to other Customers or Customer classes for the provision of Electric Power to the new load.
Demarcation Point	A designated point on the Customer's property, at which Grant PUD's Facilities end and the Customer's Facilities begin. This can be for either an overhead or underground primary metered service.
Distribution System	That part of Grant PUD's Facilities operated nominally at 13.2 kV and 12.47 kV voltage levels and used to distribute and deliver Electric Power to the Demarcation Point.
Domestic Electric Service or Domestic Service	Single phase electric connection to Grant PUDs Distribution System for deliveries of Electric Power under a Rate Schedule exclusively to single family dwellings, individual apartments, condominiums and farms.

Term	Definition
Effective Electric Service Date	The date upon which a Customer accepts delivery of Electric Power under a Rate Schedule at the Account Premises by having the power turned on (made available) and the service placed in or transferred to their name.
Electric Power	The physical electric energy and capacity provided by Grant PUD, including all ancillary services, independent of the Rate Schedule under which the Customer is receiving Electric Service.
Electric Service	Electric Power delivered to a Customer under a Rate Schedule.
Electric Service Connection Agreement	An agreement between Grant PUD and the Customer, which must be signed by the Customer when applying for a Line Extension from Grant PUD.
Electric Service Suspension Notice	A reminder letter, sent separately from the billing statement, to inform Customers of past due amounts and provide instructions to prevent their service from being disconnected for non-payment.
Electric System	Grant PUD's infrastructure used to generate, transmit, and deliver Electric Power to its Customers.
Estimated Extension Cost	The estimated cost, based on current Grant PUD standard unit values, for a line extension. The estimate includes all material, labor, transportation, and applicable overheads with credit for any salvage.
Evolving Industry	Evolving Industry (or EI) is the class covered by Rate Schedule 17.
Facilities Plan	The document that contains detailed information about the electric Facilities Grant PUD is constructing intended to deliver Electric Power to a Customer.
Facility or Facilities	The physical land, equipment, wire, cable and appurtenances in a location or a group of locations.
False Call Fee	A charge paid by a customer that requests Grant PUD service and is not prepared when Grant PUD arrives on site at the requested timeframe.
Fiber Subscriber	A person or entity that is receiving access to Telecommunication Services from a Service Provider.
Grant PUD Construction Standards	A set of rules, drawings, guidelines, and specifications for construction of Electric Power Facilities, established by the Grant PUD Standards group. These standards secure uniform construction methods, optimize safety, serviceability, appearance, and economy and comply with or exceed local, state and federal regulations.
Hearing Officer	Commission-appointed person responsible for adjudicating contested bills not resolved to the Customer's satisfaction working through the Customer Care Team(s).
Identified Uses	The industry, functions, applications or uses included in Rate Schedule 17 as determined by the Rate Schedule 17 review process.
Industry	Grant PUD classifies industries based on activities that represent a means of production, target a market, produce a product and/or provide a service. Activities are grouped together such that the risk characteristics of the grouped activities are similar and can be analyzed as a single industry. It is possible for a Customer to participate in multiple Industries.

Term	Definition
Irrigation Electric Service	Electric Service used specifically for irrigation, orchard temperature control or soil drainage loads only not exceeding 2,500 horsepower. Electric Power delivered under the Irrigation Rate Schedule(s) may only be used as described in the Rate Schedule including any supporting ancillary equipment needed.
Large Electric Service	Electric Service provided to Large Power Customers.
Large Electric Service Application	Application form for Large Power Customers (available at grantpud.org) used to request new or additional Electric Service from the Grant PUD. While all Customers are required to inform Grant PUD of all material load changes, Large Power Customers must use this form to inform Grant PUD.
Large Power Customer	Customers with electric loads exceeding 500 kW/kVA who accept Electric Power under a Rate Schedule 7, 14, 15, 16, 17, 85, 94 or a written agreement for Electric Power deliveries with Grant PUD that is not delivered under a current Rate Schedule.
Line Extension	Any customer projects requiring the outlay of materials and labor in excess of the limitations of a Simple Service shall be considered a Line Extension. These extensions require an electrical design prior to construction and may involve right-of-way requirements in excess of those provided for by the Service Connection Agreement. Facilities that are designated as part of an Area Feeder are not included in the definition of Line Extension.
Line Extension Fee	The applicable Customer paid fees for a Line Extension. (Refer to Section 4.5.1.)
Net Metering Application	The application provided by the Customer to Grant PUD, on Grant PUD's form, which provides the design of the Net Metering system and initiates the interconnection process.
Net Metering Interconnection Agreement	An agreement provided by Grant PUD to the Customer setting forth the terms and conditions for allowing a Customer to interconnect an energy producing Customer-owned resource. Customers may not connect a Net Metering System without written approval by Grant PUD and execution of a Net Metering Interconnection Agreement.
Net Metering System	As defined in RCW 80.60.010, means a fuel cell, a facility that produces electricity and used and useful thermal energy from a common fuel source, or a facility for the production of electrical energy that generates renewable energy, and that: <ul style="list-style-type: none"> (a) Has an electrical generating capacity of not more than one hundred (100) kilowatts; (b) Is located on the customer-generator's premises; (c) Operates in parallel with the electric utility's transmission and distribution facilities; and Is intended primarily to offset part or all of the customer-generator's requirements for electricity.
New Large Load	An increase of any load(s) over 10 average MW of a Customer's annual average load (average MW) above the Customer's highest annual average load since 2010.
Orchard Temperature Control	Frost control fans or pumps used in the heating or cooling of orchards.

Term	Definition
Ownership Costs	A monthly charge required to be paid by the Customer for Non-Permanent service. The charge reflects costs associated with Grant PUD owning, operating and maintaining the Non-Permanent facilities. This charge is for use of the facilities only and does not include Electric Service. The charge is calculated using standard Grant PUD accounting practices.
Premises	The building and land that constitutes the location where a Customer will be accepting Electric Power under a Rate Schedule and this Customer Service Policy. Premises is both singular and plural.
Rate Schedule	Any Commission approved method to calculate a Customer's bill for Electric Service for a given time frame, determined by service dates. The methods describe the billing components such as minimum fees, basic charges, cost of the various billing determinants such as energy use and billing demand. Rate Schedules can be found at grantpud.org .
Renewable Energy	As defined in RCW 80.60.010, means "energy generated by a facility that uses water, wind, solar energy, or biogas from animal waste as a fuel".
Secondary Service	The wire providing service from Grant PUD's facilities to a Customer's meter.
Simple Service	Any Customer project that only requires a Customer's secondary service wire to be connected to Grant PUD's existing facilities. This would include any inspections needed as well as making the final connection and setting the meter.
Simple Service Fee	A Customer paid charge that is collected for a Simple Service.
Start of Electric Service	The date and time when a Customer starts accepting deliveries of Electric Power under an approved Rate Schedule.
Termination Charge	A Customer paid amount to reflect the Grant PUD's costs to remove Line Extension Facilities no longer being used by the Customer. The amount to be paid by the Customer shall reflect the cost of labor to remove the Line Extension plus a pro-rated portion of any unsalvageable equipment and materials.
Up and Down Charge	Customer paid amount for Grant PUD to providing install or construct non-permanent Facilities for the delivery of Electric Service on short-term, interim or provisional basis. The charge shall be based on all
VAR kVAR MVAR	A technical term that refers to the component of the Electric Power that is not used to perform work such as rotating the shaft of an electric motor but provides the component that maintains voltage and provides the magnetic field required to turn an Electric motor's shaft. Sometimes this term is also referred to as 'reactive power'. The prefix k and M stand for one thousand (1,000) and one million (1,000,000) respectively. kVAR means kilovolt-ampere reactive and MVAR means megavolt- ampere reactive.
VARh kVARh MVARh	The amount of reactive power, measured in VAR delivered in one hour. The prefix k and M stand for one thousand (1,000) and one million (1,000,000) respectively. kVARh means kilovolt-ampere reactive hour and is often used to calculate Billing Determinants by Grant PUD and MVARh means megavolt-ampere reactive hour, more commonly used in wholesale electric markets.

Term	Definition
Volt-ampere (VA) (kVA, MVA)	<p>The product of the current and voltage of a load. Represents the total burden the load places on the Electric System. Often referred to as 'apparent power' it is generally the limiting characteristic of Facilities.</p> <p>The prefix k and M stand for one thousand (1,000) and one million (1,000,000) respectively. kVA means kilovolt-ampere and MVA means megavolt-ampere.</p>
Watt kW MW	<p>The measurement of power in the International System of Units (SI) the equivalent of horsepower in the English measurement system. Watts are the component of volt-amperes that perform work such as rotate the shaft of an electric motor or produce light from a light bulb.</p> <p>The prefix k and M stand for one thousand (1,000) and one million (1,000,000) respectively. kW means kilowatt and MW means megawatt.</p>
kWh	<p>Kilowatt-hour and is the most common billing determinant used by Grant PUD representing the amount of Electric Power, measured in thousands of watts delivered in one hour. The prefix k stands for one thousand (1,000).</p>

2.0 GENERAL POLICIES

2.1 RATE APPLICABILITY

2.1.1 Metering Point

The rates of Grant PUD are based upon the supply of service to the entire premises through a single metering point. Separate metering points will be billed individually unless aggregated for Large Power Customer Electric Service Above 500 kW/kVa. Refer to Section 8.0.

2.1.2 Determination of Applicability

Grant PUD shall determine the applicable rate schedule to be applied for each Customer load based on available information. In the case of multiple Customer meters or facilities, Grant PUD reserves the right to aggregate Customer loads and meter reads for purposes of determining the applicable rate schedule. If over time a Customer's electrical usage or load characteristics change in a way that would qualify the Customer to be on a different rate schedule, it shall be the obligation of the Customer to notify Grant PUD of such changes. Changes in applicable rate schedules will be made on a prospective basis only.

If a Customer exceeds the billing demand limit of their current rate schedule they may be moved to the appropriate schedule for future billings. If the Customer has been below the billing demand limit of their current rate schedule for a period of at least (12) consecutive calendar months they may request Grant PUD move them to the rate schedule appropriate for their current billing demand.

2.2 RATE SCHEDULES

The rates of Grant PUD are based upon a balance between electric service requirements, environmental considerations, and cost. Rate schedules have been adopted by Grant PUD's Commission to establish charges for service according to classification of Customers. Copies of the rate schedules are available upon request.

Schedule No. 1	Domestic Service
Schedule No. 2	General Service
Schedule No. 3	Irrigation Service
Schedule No. 6	Street Lighting Service
Schedule No. 7	Large General Service
Schedule No. 13	Alternative Energy Resources
Schedule No. 13SS	Specified Source Purchase
Schedule No. 13REC	Renewable Energy Certificate Purchase
Schedule No. 14	Industrial Service
Schedule No. 15	Large Industrial Service
Schedule No. 16	Agricultural Food Processing Service
Schedule No. 17	Evolving Industry Service
Schedule No. 85	Agricultural Food Processing Boiler Service
Schedule No. 94	New Large Load Service

2.2.1 Rate Schedule Exceptions

Service may be supplied to Customers not coming within the scope of the regular rate schedules of Grant PUD; provided that such service shall be covered by separate contract and shall be approved by the Commissioners of Grant PUD.

2.3 NEW LOADS

Service to New Large Loads will only be made pursuant to Rate Schedule No. 94, New Large Load Service.

2.4 EXCLUSIVE SOURCE AND RESALE

Unless otherwise provided by special contract, service will be rendered only to those loads which secure their source of electric power exclusively from Grant PUD. Unless otherwise provided in the contract, the Customer shall not resell the electric energy purchased from Grant PUD.

2.5 GRANT PUD'S OBLIGATIONS

Grant PUD will attempt to provide, but does not guarantee, a regular and uninterrupted supply of service. Grant PUD may suspend the delivery of electric service for the purpose of making repairs or improvements to its system. Grant PUD will attempt to provide reasonable advance notice of such suspension to the Customer. Repairs or improvements that can be scheduled will be scheduled, when feasible, at such time as to minimize impact to Grant PUD Customers. In making repairs and improvements to Grant PUD's electrical system, Grant PUD will do so with diligence and complete them as soon as reasonably practicable in accordance with prudent utility practice. Electric Service is inherently subject to interruption, suspension, curtailment and fluctuation. In no event, however, shall Grant PUD be liable to its Customers or any other persons for any damages to person or property arising out of, or related to, any interruption, suspension, curtailment or fluctuation in service if such interruption, suspension, curtailment or fluctuation results in whole or part from any of the following:

- A. Causes beyond Grant PUD's reasonable control including, but not limited to, accident or casualty, fire, flood, drought, wind, acts of the elements, court orders, insurrections or riots, generation failures, lack of sufficient generating capacity, breakdowns of or damage to equipment/facilities of Grant PUD or of third parties, acts of God or public enemy, strikes or other labor disputes, civil, military or governmental authority, electrical disturbances originating on or transmitted through electrical systems with which Grant PUD's system is interconnected and acts or omissions of third parties.
- B. Repair, maintenance, improvement, renewal or replacement work on Grant PUD's electrical system, which work, in the sole judgment of Grant PUD, is necessary or prudent.
- C. Automatic or manual actions taken by Grant PUD, which in its sole judgment are necessary or prudent to protect the performance, integrity, reliability or stability of Grant PUD's electrical system or any electrical system with which it is interconnected. Such actions shall include, but shall not be limited to, the operation of automatic or manual protection equipment installed in Company's electrical system, including, without limitation, such equipment as automatic relays, generator controls, circuit breakers, and switches. Automatic equipment is preset to operate under certain prescribed conditions, which in the sole judgment of Grant PUD, threaten system performance, integrity, reliability and stability.
- D. Actions taken to conserve energy.

The limitation of liability provisions set forth above and in Section 2.5.1 shall apply notwithstanding any negligence of Grant PUD, unless the actions of Grant PUD are determined to be intentional or shall constitute gross negligence.

2.5.1 Limitations of Damages

In no event shall Grant PUD have any obligation or liability for any lost profits, consequential, incidental, indirect, special, or punitive damages of any type arising out of, or in any way connected to, Grant PUD's supply electricity or any interruption, suspension, curtailment or fluctuation thereof regardless of the causes thereof.

2.6 CUSTOMER'S OBLIGATIONS

2.6.1 Increased Load

In the event the Customer desires to increase load, the Customer shall request new service from Grant PUD. If the Customer fails to notify Grant PUD and Grant PUD's equipment is damaged as a result of such increase in load, the Customer shall reimburse for all repair and replacement costs to Grant PUD.

2.6.2 Balancing of Load

Except in the case of three-phase four-wire delta services, the current unbalance in three-phase services shall not exceed 10 percent of the current, which would be required at maximum load under balanced conditions.

2.6.3 Total Harmonic Distortion (THD)

1. The application of any nonlinear load by the Customer (e.g., static power converters, arc furnaces, adjustable speed drive systems, etc.) shall not cause voltage and/or current Total Harmonic Distortion (THD) levels greater than the levels as recommended by IEEE standard 519-1992, or subsequent revision, on Grant PUD's electric system at the point of power delivery to the Customer's facility. Grant PUD will determine the appropriate SCR (short circuit ratio) at the Customer's facility for the purpose of applying IEEE 519.
2. The Customer shall disclose to Grant PUD all nonlinear loads prior to connection. Grant PUD may test the Customer's load to determine the THD levels.
3. It shall be the responsibility of the Customer to assure that the THD requirements are met, including the purchase of necessary filtering equipment. Any load found not in compliance with this policy shall be corrected immediately by the Customer at the Customer's expense. If not corrected, Grant PUD may terminate service to the Customer's facility.
4. The Customer shall be liable for all damages, losses, claims, costs, expenses and liabilities of any kind or nature arising out of, caused by, or in any way connected with the application by the Customer of any nonlinear load operating with maximum THD levels in excess of the values stated in paragraph 1. The Customer shall hold harmless and indemnify Grant PUD from and against any claims, losses, costs of investigation, expenses, reasonable attorneys' fees, damages and liabilities of any kind or nature arising out of, caused by, or in any way connected with the application by the Customer of any nonlinear load operating with maximum THD levels in excess of the values stated in paragraph 1.

2.6.4 Surge Protection

The Customer shall be responsible to provide surge protection for all voltage sensitive equipment such as electronic appliances or devices.

2.7 APPLICATION FOR SERVICE

Grant PUD will accept application for electric service over the telephone or by personal visit to any of Grant PUD's Local Offices and the following shall apply:

- A. All applicants for electric service shall provide Grant PUD with service and billing information as required and agree to Grant PUD's terms and conditions for service.
- B. Acceptance of service shall subject the Customer to compliance with the terms of the applicable rate schedule, Grant PUD's Customer Service Policies, Grant PUD Workbooks and Initiatives. The Customer is responsible for all electricity used until notification of the change in occupancy has been received by Grant PUD.

- C. All applicants shall provide the following information or documentation:
 1. A full name, mailing address and service address where services are to be delivered.
 2. Full name of any occupants over 18 years of age living where services are to be delivered who are authorized to conduct transactions on the account.
 3. Proof of identity, such as a valid social security number and/or government-issued picture identification. Other identification may be accepted at Grant PUD's discretion provided it convincingly proves the identity of the prospective Customer.
 4. At least one active primary telephone number and email address (if available) where the Customer can be contacted.
 5. Whether service termination would create a danger to the health of any occupant(s) residing therein.

2.8 DISCONNECTING SERVICES

Customers requesting service disconnects must contact Grant PUD by telephone or in person. Grant PUD will execute service disconnects according to the following:

- A. At the time a Customer requests service disconnect Grant PUD will attempt to verify (1) the individual's identity by personal recognition, social security number, driver's license or other identification, (2) the authority of the individual to request the disconnect when there is reason to question the identity of the requesting party, (3) the name and mailing address of the occupant of the residence where electric service is to be terminated, and (4) whether any occupant would be endangered by the termination of service. If Grant PUD obtains information that the residence is being occupied by someone other than the person making the termination request, Grant PUD will inform such person that services may not be discontinued until the occupant is given a minimum period of five days to put service in his/her own name.
- B. If Grant PUD has no reason to believe that the premises are occupied by a person other than the one making the request, or that any occupant's health will be endangered, Grant PUD may proceed to terminate electric service. However, before service is terminated, the employee executing the non-remote disconnect will make a reasonable effort to inspect the property for which termination has been requested in order to ascertain whether the property is occupied by persons other than the one making the termination request or to determine whether extenuating circumstances, such as conditions endangering life or property, may result from the disconnect. If such circumstances appear to exist, or if Grant PUD has actual notice or reason to believe that someone other than the person requesting the termination is residing at the premises, then a five-day notice will be left at the premises and the disconnect will be held in abeyance until an investigation can be made by the Local Office.
- C. Where Grant PUD does not have reasonable belief after inspection that someone other than the person requesting termination occupies the premises, or that extenuating circumstances exist, such as life or property-endangering conditions, Grant PUD may terminate service. However, in the event Grant PUD fulfills the request to terminate utility service, it may post on the door of the property a notice which will inform any occupants of the premises that they may request immediate restoration of the utility service.
- D. For single-family units or individually-metered multi-family units, if the premises are occupied by a person other than the Customer of record, Grant PUD will upon request transfer electric service into the occupant's name. With respect to such transfer of service:

the occupant will not be responsible for any charges accrued prior to the date notice of opportunity to place service in the user's name is provided (except where occupant has agreed by lease to pay for electrical service, in which case charges will begin on the date the tenancy began).

- E. For residential buildings containing more than one dwelling unit in which service is not individually provided, a five-day notice will be provided giving the occupants an opportunity to put service in their own name(s).
- F. Refer to Section 6.18 of these policies for disconnects for nonpayment.

2.9 LIFE SUPPORT SYSTEMS

Grant PUD is unable to guarantee constant or continuous electric service. Grant PUD will make reasonable effort to notify all known electrically supplied life support system Customers of planned power outages, in advance, giving the date, time and estimated length of planned power outages.

2.9.1 Customer Obligations

It shall be the responsibility of the Customer to furnish Grant PUD by phone or in writing a telephone number and/or email address which will enable timely contact by Grant PUD 24 hours per day, 365 days per year and to notify Grant PUD of any change in telephone number and/or email address; and of any change in the medical situation of the person on life support services. If a customer no longer has life support, it shall be the responsibility of the customer to notify Grant PUD.

2.10 DAMAGE TO GRANT PUD FACILITIES

Each individual, group, or organization shall pay Grant PUD for all damages to, or destruction of, property of Grant PUD where such is caused by the individual, group, or organization, except that Grant PUD will not require payment for accidental damage to poles resulting from weed and brush burning. Customer shall be responsible to reimburse Grant PUD for any damage to Grant PUD transformers or other Grant PUD facilities, caused by Customer overloading said facilities.

2.11 DISCLOSURE OF PUBLIC RECORDS

Public records of Grant PUD are available for inspection and copying. Policies and procedures related to disclosure of public records are available on Grant PUD's Web site or can be requested by contacting our offices.

2.12 SERVICE OUTSIDE GRANT COUNTY

Grant PUD will only serve loads outside of Grant County in areas that are covered under Agreements with the serving utility for the area. Service shall be in accordance with the terms of the Agreement. Requests for service outside of Grant County in areas not covered under an Agreement will be considered on an individual basis by Grant PUD's Commissioners. Refer to Section 4.5, Calculation of Charges, for Customer cost obligations for service outside Grant County.

2.13 UNDERGROUND FACILITIES

Grant PUD will install electrical facilities underground at Grant PUD expense in the following situations:

- A. Substation underground feeder get-a-ways.
- B. When determined by Grant PUD that applicable electrical codes or public safety considerations require placement of electrical facilities underground.
- C. Transmission lines and Area Feeders where it is more economically beneficial to Grant PUD to place electrical facilities underground. In making this determination, Grant PUD will consider capital investment costs, projected operations and maintenance costs, and public safety consideration.

- D. Except as otherwise specifically provided above or in Section 4.2 of these Customer Service Policies, all costs incurred by Grant PUD in connection with placement of electrical facilities underground shall be the responsibility and paid by the Customer or municipality requesting or requiring underground service.

2.14 REVENUE PROTECTION AND POWER DIVERSION

The purpose of Grant PUD's Revenue Protection Policy is to reduce or eliminate revenue loss due to metering defects and power diversion. The policy establishes a program for the prevention, detection and responsive action to be taken with regard to power diversion on Grant PUD's system.

The significant elements of this policy include the following:

- A. Meter Seals. All Grant PUD meters and associated equipment utilized for billing purposes will be sealed. Included will be meters utilized for measuring KWH, KW, KVARH, potential and current transformer enclosures and test switches.
- B. Meter Sealing Fee. If a service has been reconnected which has been previously disconnected or a meter seal has been cut on an active service WITHOUT PRIOR AUTHORIZATION from Grant PUD, a fee will be charged to the Customer, owner, or person in control of the premises, refer to fee schedule. Prior authorization may be obtained from Grant PUD. Additional fees shall be assessed if power diversion has occurred.
- C. Meter Testing. Grant PUD meters utilized for billing purposes will be tested periodically to assure all meters operate within the accuracy limits established for each type and class of meter.
- D. Power Diversion/Theft of Power. Diversion of power, as defined in RCW 80.28.240, is strictly prohibited. The Customer, owner, or person in control of the premises will be presumed liable for all losses, damages and costs related to such actions.
- E. Violations. Grant PUD may seek prosecution for any power diversion, destruction of Grant PUD property and other violations of law affecting delivery of its services, and will pursue collection for any losses, damages and costs related to such actions to the full extent provided by law.
- F. Investigations. Grant PUD personnel will determine if power diversion has occurred. A preliminary investigation shall include an evaluation of the Customer's account history, examination of on-site conditions by appropriate personnel and other pertinent information.
- G. Notice. After the investigation is complete and Grant PUD determines that power diversion has occurred, the Customer shall be notified that power diversion has occurred and:
1. The Customer has been assessed all of the damages, if any, plus the costs incurred on account of the bypassing, tampering, or unauthorized reconnection, including, but not limited to, costs and expenses for investigation, disconnection, reconnection and service calls;
 2. The Customer may be billed up to triple the amount of actual damages as provided by RCW 80.28.240; and
 3. That all sums due must be paid within 30 days unless other arrangements acceptable to Grant PUD are made;
 4. If a civil action becomes necessary, Grant PUD shall seek to recover its costs of suit, reasonable attorneys' fees and expert witness fees; and

- H. Connection and Disconnection. Grant PUD may refuse to connect or may disconnect service to a Customer for unlawful current diversion, theft of power or other violation of Grant PUD's Customer Service Policy, until all charges, losses and damages have been paid in full or other arrangements acceptable to Grant PUD have been made. Grant PUD will attempt to give the Customer reasonable advance notice of the disconnection including the reasons for the disconnection and the time of the disconnection.

2.15 INFORMAL CONFERENCE / HEARINGS

Customers having questions about or disputing the application of these policies billings or Rate Schedules may request an informal conference with a Grant PUD representative by calling a Grant PUD Customer Solutions Supervisor or Manager. The informal conference may be conducted by telephone or in person at the Customer's request. The Customer may present any information which the Customer deems relevant to the matter. If, following the informal conference, the Customer wishes to pursue the matter, the Customer may request a hearing with Grant PUD's designated Hearing Officer. The hearing will be scheduled at a mutually convenient time and the Hearing Officer shall render his or her decision in writing as soon as practical.

3.0 CONSERVATION

Grant PUD recognizes the value of conservation and retail energy services. Therefore, the Energy Services Department shall pursue cost-effective energy conservation resources. A current list of all available programs is available from Grant PUD's Energy Services Department. Any use of Grant PUD funds for conservation purposes shall be in accordance with applicable laws.

3.1 DEMAND RESPONSE

Grant PUD recognizes that wholesale electric prices and various operational constraints can materially impact its overall cost to serve its customers. The ability to work with Customers to schedule or manage when electric power is consumed (Demand Response) provides value to all Customers, not just the participants. Grant PUD staff may develop rate schedules to capture seasonal, monthly, weekly, daily, or hourly value. In addition, Grant PUD may work with certain customers or groups of customers to develop Demand Response arrangements such as avoiding placing incremental load on or reducing loads on Grant PUD's electric system for safety improvement, economic benefit, operational flexibility, or reliability purposes provided the arrangement is designed to reduce Grant PUD's power costs or generates incremental value for all its Customers. Customers who are able to participate in Demand Response will typically receive the benefit in the form of a billing credit unless specific arrangements are made prior to entering into the activity.

3.2 RESIDENTIAL, COMMERCIAL, INDUSTRIAL AND IRRIGATION ASSISTANCE

Any Customer of Grant PUD, in these sectors, is eligible for conservation assistance to the extent Grant PUD has the necessary equipment and expertise to provide it. Rebates and /or cost sharing will be offered as provided by Washington State Law and to the extent funding is available and cost effective to Grant PUD.

4.0 LINE EXTENSION POLICY FOR CUSTOMER SERVICES UNDER 500 KW

A Line Extension is an addition or modification of electrical equipment and/or an increase in the size or length of Grant PUD's existing electrical facilities to serve new customer electric load within Grant PUD's service area. Line Extensions are categorized as consisting of either Overhead or Underground electrical facilities or a combination of both.

Grant PUD will extend or modify its facilities through Simple Service or Line Extensions to Permanent, Non-Permanent or Construction Temporary Services. Facilities will be extended to provide service under applicable Rate Schedules in accordance with Grant PUD Construction Standards. Customer supplied fiber optic conduit is for Grant PUD fiber optic cable only. Each line extension will be subject to evaluation as to feasibility, permanence, and compatibility with Grant PUD's system. Final determination as to specific conditions applicable to the extension, type of construction, route and design shall be made solely by Grant PUD.

Customer compliance with Grant PUD Policies and Construction Standards are a condition of service. The Customer is required to sign a Service Connection Agreement for any proposed Line Extension and pay any applicable Line Extension Fees.

4.1 OVERHEAD LINE EXTENSIONS

When Grant PUD determines overhead facilities should be installed to serve a Customer, at the Customer's expense, Grant PUD will provide and install all materials and equipment necessary to provide said service from its existing facilities to the Connection Point in accordance with current Grant PUD Construction Standards. Grant PUD will own and maintain all overhead Secondary Services after they are energized.

4.2 UNDERGROUND LINE EXTENSIONS

When the District determines underground facilities should be installed to serve a Customer, the installation shall be made on the same basis as overhead and in conformance with all other District policies and standards applicable to underground service (refer to Section 4.11 for Customer obligations for Backbone Facilities).

Grant PUD will own and maintain all underground Secondary Services providing power to any single family home, any single unit manufactured/mobile home, any irrigation service fed directly from a pole to the meter (if meter is within twenty feet of the pole), and any single structure duplex. The Customer will own all underground Secondary Services providing power to commercial buildings, multi-family buildings, mobile home parks, and potentially others not mentioned here.

Examples

- A. Single house on an individual lot – Grant PUD owns the secondary wire from the connection point to the meter.
- B. Single mobile home on an individual lot – Grant PUD owns the secondary wire from the connection point to the meter.
- C. One duplex on an individual lot – Grant PUD owns the secondary wire from the connection point to the meter.
- D. Irrigation service for a crop – Grant PUD owns the secondary wire from the pole to the metering equipment as long as the metering equipment is within twenty feet of the pole.
- E. Small or large commercial building on an individual lot – Customer owns the secondary wire from the connection point to the metering equipment.
- F. Two or more duplexes on the same lot – Customer owns the secondary wire from the connection point to the metering equipment.
- G. Any service inside of a mobile home park – Customer owns the secondary wire from the connection point to the metering equipment.

- H. Multi-unit building on an individual lot – Customer owns the secondary wire from the connection point to the metering equipment.
- I. One meter controlling landscape lighting and sprinkler system at an entrance to a plat – Customer owns the secondary wire from the connection point to the metering equipment.

4.3 TYPES OF SERVICE

4.3.1 Permanent Service

For Line Extensions to permanent electric loads, all of the following conditions must be met:

- A. The need for electricity is intended to be permanent in the location applied for.
- B. The property owner must sign a Service Connection Agreement.
- C. The Customer must furnish all necessary permits, licenses and other governmental approvals required in connection with the line extension.
- D. When deemed necessary by Grant PUD, the Customer shall provide perpetual easements, permits and/or licenses required in connection with the line extension.
- E. For all water pumping loads, excluding domestic wells, Grant PUD reserves the right to require the Customer to provide a written permit from the agency having jurisdiction over the water to be pumped.
- F. The Customer shall make payment of the Line Extension Fee as specified in Section 4.5.1.

Service to electric loads meeting all of the conditions as set forth above shall be considered permanent.

4.3.2 Non-Permanent Service

When a Customer requesting a Line Extension cannot meet the conditions set forth in Section 4.3.1 above, non-permanent service may be extended under the following conditions:

- A. The Customer must sign a Service Connection Agreement.
- B. The Customer must pay the estimated Up and Down Charge and a monthly facility charge equal to Grant PUD’s Ownership Cost for the line extension as specified in Section 4.5.1. The facility charge shall continue until the Customer notifies Grant PUD to discontinue the service or when all permanency requirements are met.
- C. In the event all permanency requirements are met, the costs for the extension shall be computed according to the applicable Line Extension Policy for permanent service (Section 4.3.1) less credit for facilities charges.

4.3.3 Construction Temporary Service

Where sufficient distribution facilities already exist, the Customer may install a metered temporary service, for the purpose of construction only. Service shall be provided for a Construction Temporary Service for a one-time designated fee to be determined by Grant PUD. Subsequent usage will be billed at the appropriate rate schedule up to one year. At the end of one year, Grant PUD will either remove the service or charge the customer the simple service connection fee and consider the service permanent.

Service may be extended for one six-month period with re-application and payment of a second Construction Temporary Service Fee. Such flat fee will be charged against the Customer’s account. Where no distribution facilities exist, refer to Section 4.3.2 for construction of Non-Permanent Service.

4.4 SERVICE REQUIREMENTS BY RATE CLASS

- A. Schedule 1, Domestic Service
 Domestic service is defined in Grant PUD rate schedules as single-phase service to single family dwellings, individual apartments or farmhouse. In addition to all other requirements for Line Extension as set forth by Section 4.0, a Customer(s) applying for said extension

for Domestic Service shall:

1. Provide and install all material, trenching, etc., necessary for electric service from the load being served to the designated Connection Point.

Refer to Section 4.11 for Customer requirements for residential (domestic) subdivisions and Section 4.12 for manufactured home parks.

B. Schedule 2, General Service

General Service is defined in Grant PUD rate schedules as single phase or three-phase service to electric loads not to exceed 500 kW (as measured by billing demand) for general service lighting, heating and power requirements, excluding irrigation service.

In addition to all other requirements for Line Extension as set forth by Section 4.0, a Customer(s) applying for said extension for General Service shall:

1. Provide and install all material, trenching, etc., as necessary for electric service from the load being served to the designated Connection Point.

Refer to Section 4.11.1 for Customer requirements for commercial subdivisions that qualify under this rate schedule.

C. Schedule 3, Irrigation Service

Irrigation Service is defined in Grant PUD rate schedules as electric service to irrigation, orchard temperature control or soil drainage loads not to exceed 2,500 horsepower and other miscellaneous power needs including lighting.

In addition to all other requirements for Line Extension as set forth by Section 4.0, a Customer(s) applying for said extension for Irrigation Service shall:

1. 1. Provide and install all material, trenching etc., as necessary for electric service from the load being served to the designated Connection Point.
2. 2. Provide and install a District-approved concrete pad for all padmount transformers 750 KVA and larger.

D. Large Electric Service

Refer to Section 8 for additional Customer requirements for Large Electric Service above 500 kW.

4.5 CALCULATION OF CHARGES

4.5.1 Line Extension Fees

A. Permanent Service:

The Customer shall pay a Line Extension fee (refer to fee schedule) for services located within Grant County, unless service qualifies for a Simple Service (See Definition of Terms, Section 1.1). The Line Extension fee may be refundable upon termination of the request, less any amounts already expended or committed by Grant PUD in relation to the Line Extension request.

For Line Extension estimates in excess of \$20,000, the Customer shall be responsible for the actual cost of the project. A Customer Service Contract must be signed when the initial estimate is paid. When the project is complete and all project costs have been accumulated, Grant PUD will either refund or invoice any differential between the actual and estimated costs to the customer.

When more than one rate schedule could apply, the maximum will be established by the rate schedule which gives the lowest billing for energy usage.

The minimum payment for any Line Extension shall be equal to the Simple Service Fee.

Customers applying for Permanent Service to an electric load outside Grant County shall be

required to pay 100% of the Estimated Extension Cost.

B. Simple Service Fees:

The Customer shall pay a non-refundable Simple Service Electric fee, refer to fee schedule.

The Customer shall pay a non-refundable Simple Service Fiber fee, refer to fee schedule.

C. Non-Permanent Service:

The Customer shall pay a non-refundable Up and Down Charge for Non-Permanent Service equal to the estimated cost of furnishing, installing and removing the required facilities, less any salvage value, for service inside or outside of Grant County. In addition, the Customer shall pay a monthly facility charge equal to Grant PUD's Ownership Costs. (See Definition of Terms, Section 1.1)

D. Construction Temporary Service:

The Customer shall pay a non-refundable Construction Temporary Service Fee, refer to fee schedule.

E. Permit Fees:

In addition to payment of the appropriate Line Extension Fee, any charges levied by any agency for permits, surveys, easements, licenses, etc. necessary for the Line Extension, shall be paid for by the Customer.

4.5.2 Line Extension Fee Payments

Charges for Simple Services, both Overhead and Underground, shall be included in the Customer's energy usage bill for the service. Charges for Line Extensions are due prior to scheduling construction.

Exception: Customers applying for Line Extensions to Backbone Facilities and/or Customers with an account(s) requiring a deposit under Section 6.14, shall be required to pay prior to energizing the service.

For projects with an estimated cost in excess of \$20,000, the Customer shall be responsible for the actual cost of the project. A Customer Service Contract must be signed when the initial estimate is paid. When the project is complete and all project costs have been accumulated, Grant PUD will provide to the Customer an itemized invoice reflecting all project costs incurred. Grant PUD will either refund or invoice any differential between the actual and estimated costs to the Customer. Final payment will be due 25 days after the invoice date. Permanent Service will be subject to disconnection if full payment is not received by the due date.

Payment of the Line Extension Fee is in addition to any energy use, deposits, or outstanding invoices that may be due. Political subdivisions of the State of Washington and Agencies of the Federal Government may make payment after Grant PUD facilities are installed provided Grant PUD has received written agreement that payment will be made in full upon completion of Grant PUD work.

4.6 MODIFICATION OF FACILITIES

Modifications are those changes to existing electrical facilities required to allow for installation of new facilities requested by a Customer. Upon request from an individual Customer Grant PUD will modify its facilities provided:

A. The Customer signs and submits a Service Connection Agreement.

B. The Customer pays the pro-rated Termination Charge for the modified facilities in addition to the appropriate Line Extension Fee for the new facilities.

C. The modifications comply with current Customer Service Policies and Grant PUD Construction Standards.

4.7 REBUILDING EXISTING LINES

When it becomes necessary to rebuild existing line to serve added electric load, the cost of the rebuild shall be considered as part of the Estimated Extension Cost for the new load except when the line is designated to be an Area Feeder. (See Section 4.10.1)

4.8 TRANSMISSION FACILITIES

Transmission facilities required to provide for general area load growth and basic system reliability will be constructed entirely at Grant PUD expense as part of an overall development plan.

4.9 SUBSTATIONS

Substations required to provide for general area load growth and basic system reliability will be constructed entirely at Grant PUD expense as part of an overall development plan.

4.10 DISTRIBUTION POWER LINES

4.10.1 Area Feeder Lines

Primary distribution lines designed to provide for general electric load growth and system reliability are designated as “Area Feeders”. These lines are constructed at Grant PUD expense, included in the rate base and limited to the following:

- A. Incorporated Cities and Towns

Primary lines along all platted streets and alleys inside or adjoining the city limits shall be designated as Area Feeders.
- B. Developed Irrigation Blocks

Primary lines along all county road and state highway rights-of-way inside or adjoining developed irrigation blocks shall be designated as Area Feeders.
- C. Proposed Irrigation Blocks

When, in the opinion of Grant PUD, the road plan and canal construction schedule has been established, all distribution lines along county road and state highway rights-of-way shall be designated as Area Feeders. When requested by a Customer to provide service inside the proposed irrigation block more than one year prior to scheduled delivery of irrigation water, Grant PUD will construct the necessary area feeders, the size and location being in accordance with the feeder plan for the block. The Customer requesting the service shall enter into an agreement to pay the annual interest on Grant PUD’s estimated investment for the Area Feeder(s). Said agreement shall continue for ten (10) years or until irrigation water is delivered to the block.

When no road plan or canal construction schedule has been established, Grant PUD will construct requested lines to serve Customer loads without consideration of the area becoming an irrigation block and the estimated construction costs shall be included as part of the Estimated Extension Cost.
- D. Sandwells Irrigation Block

Primary lines along all established and legally recorded county road and state highway rights-of-way inside or adjoining the Sandwells area shall be designated as Area Feeders. (Refer to Grant PUD maps for boundaries of the Sandwells area.)
- E. Other

Certain distribution facilities that extend into areas of anticipated development or that are for the purpose of system reliability may be designated as Area Feeders at the sole discretion of Grant PUD.

4.10.2 Distribution Power Lines That Are Not Area Feeders

Essentially, a “Non-Area Feeder” is any primary distribution line not meeting the criteria established

by Section 4.10.1. Additionally, Extensions (Backbone Facilities) into residential and commercial subdivisions shall not be considered Area Feeders. Construction costs for distribution lines that are not designated, as Area Feeders shall be included as part of the Estimated Extension Cost except as follows:

- A. When it is deemed necessary by Grant PUD to add a distribution system neutral conductor to an existing power line, Grant PUD will pay 100% of the construction cost for the addition of the system neutral.

4.11 EXTENSIONS TO RESIDENTIAL/COMMERCIAL SUBDIVISIONS

4.11.1 Approved Subdivisions

Grant PUD will extend electric service to any new city or county approved subdivision according to the following conditions:

- A. The Customer must provide a Backbone Facility design in accordance with Grant PUD Construction Standards, subject to Grant PUD approval.
- B. The Customer must pay the appropriate Line Extension Fee as required by Section 4.5.1, prior to construction.
- C. All trenching, conduit, transformer boxes, pads, junction boxes, sand bedding and backfill shall be provided and installed by the Customer in accordance with Grant PUD Construction Standards.
- D. The costs for Off-Site Facilities or Line Extensions outside the boundaries of a residential or commercial subdivision necessary for providing service to the subdivision, will be included as part of the Estimated Line Extension Costs for the subdivision.

4.11.2 Services within a Subdivision

Grant PUD facilities installed in addition to a Backbone Facility to serve individual Customers shall be considered a separate Extension and subject to the appropriate Section(s) of Line Extension Policy 4.0.

Where Backbone Facilities have not been provided for by a developer, any Customer(s) requesting service within the subdivision shall be responsible for the necessary Backbone Facilities in accordance with Line Extension Policy, Section 4.11, as if he/she were the developer.

4.12 MANUFACTURED HOME / MOBILE HOME PARKS

Line Extensions will be made to new manufactured home parks and additions will be made to existing mobile home/manufactured home parks under the following conditions:

- A. If the Line Extension is considered to be permanent, construction will be done in accordance with the Line Extension Policy, Section 4.11.1.
- B. Grant PUD will consider a Line Extension permanent in cases where the Customer makes a substantial permanent investment in other improvements. This requirement will be satisfied when initial improvements include permanent water and sewer facilities, graded and paved or graveled streets and electric service entrance capability at each manufactured home or mobile home space.
- C. Grant PUD will provide the appropriate electrical system to the Connection Point(s). For an individual manufactured/mobile home, the Connection Point will be at the moped/pedestal, and Grant PUD will own and maintain the underground conduit and secondary service wire up to the meter after the service is energized. For manufactured/mobile homes within a mobile home park, the Connection Point will either be at the transformer or at the moped/pedestal and will be dependent on the design. For manufactured/mobile homes within a mobile home park, the Customer will own and maintain the underground conduit and secondary service wire from the Connection Point to the meter(s) after the service is energized.

4.13 UNUSED IRRIGATION SERVICE FACILITIES

Grant PUD-owned irrigation service facilities may be removed by Grant PUD at any time following disconnection for nonpayment of arrears from a previous irrigation billing season.

5.0 SERVICE AND METER REGULATIONS

5.1 AVAILABILITY AND CONDITIONS OF SERVICE

5.1.1 Determination of Availability

The availability of service for the equipment to be used shall be determined by Grant PUD before proceeding with the wiring or the installation of equipment. Grant PUD shall advise the Customer of the available phase and voltage for that service, and of any required reduced voltage motor starting equipment to protect the service to its other customers (see Section 5.3.3).

5.1.2 Compliance with Regulations and Codes

The Customer's wiring and equipment shall comply with State, Municipal and Grant PUD regulations, the National Electrical Code and the National Electrical Safety Code. Grant PUD reserves the right to discontinue service at any time, or refuse to connect where such service will adversely affect the service to its Customers, or where the Customer has not complied with said regulations and codes, or where the Customer's equipment or wiring are found to be defective or dangerous, until the same are repaired to the satisfaction of Grant PUD; however, Grant PUD is not obligated to inspect the Customer's electrical property and assumes no liability for the condition of, or resultant damage or injury from, the Customer's electrical property.

5.1.3 Access to and Care of Grant PUD Property

Grant PUD shall have the right, through its employees or other agents, to enter upon the premises of the Customer at all times for the purpose of reading, inspecting, repairing or removing the metering devices, appliances and wiring owned by Grant PUD. The Customer shall provide space for, and exercise proper care to protect Grant PUD property on the Customer's premises. Such property shall include, but is not limited to, meters, instrument transformers, wires and other facilities installed by Grant PUD. In the event of damage to Grant PUD property, the Customer, owner, or person in control will be presumed to be liable for the cost to repair or replace Grant PUD property, which is damaged or destroyed. If power diversion has occurred, Grant PUD may recover additional costs, expenses, and damages as provided under Customer Service Policy 2.14 or other applicable law. Additionally, the Customer shall have such rights to conferences with Grant PUD personnel as are provided in Customer Service Policy 2.14.

5.1.4 Customer Responsibility

Nothing in these Policies shall be construed as placing upon Grant PUD any responsibility for the condition of the Customer's wiring or equipment, and Grant PUD shall not be held liable for any loss or damage resulting from defects in the Customer's installation and shall not be held liable for damage to persons or property arising from the use of the service on the premises of the Customer.

5.1.5 Separate Services

Grant PUD will not totalize metering of separate services. Where Grant PUD contracts to furnish separate transformers to provide multiple services or multiple voltages for the mutual benefit of Grant PUD and the Customer, metering and billing shall be either by separate services at low voltage or consolidated at high voltage and include transformation losses.

Separate Customers shall have separate metering and separate accounts, subject to the conditions set forth in Section 2.1.1. Grant PUD will not allow two or more separate customers to combine or totalize metering.

5.1.6 Backup and Maintenance Power

Backup power and maintenance power will be provided by Grant PUD upon request, to Cogeneration and Small Power Production Facilities as defined under the Public Utilities Regulatory Policies Act of 1978. Grant PUD shall provide excitation power during interconnected parallel operations with Cogeneration and Small Power Production Facilities of 100 kW or less.

5.1.7 Station Service - Customer Owned

Station Service Power for Customer-owned generating facilities will be provided by Grant PUD only when the facility is not generating power.

5.2 SERVICE LATERAL AND POINT OF CONNECTION

The route of the service and the location of the service connection and metering equipment shall be determined by Grant PUD. Any wiring not complying with these Policies and installed without first determining the location of the service connection and/or meters will have to be brought into compliance with these Policies upon notification by Grant PUD.

5.2.1 Overhead Service Laterals

- A. For overhead service, the service entrance shall be so located that the secondary service wires installed by Grant PUD will reach the service entrance by attachment at one location only on the building.
- B. The point of service attachment of an overhead service on the building shall be of sufficient height to provide the required ground clearance for secondary service drop conductors. A service mast or other approved structure to terminate secondary service conductors or reinforcement of the building for adequate anchorage shall be provided and installed by the Customer or their contractor. Grant PUD will supply, for installation by the Customer, anchor bolts for service attachments to concrete, masonry, or other buildings where necessary.
- C. Only one set of service entrance conductors will be connected to any one overhead secondary service drop except by special approval of Grant PUD.
- D. Grant PUD will supply and install, as part of the Customer extension costs, meter poles for overhead services. The meter pole shall then be owned and maintained by the Customer.
- E. Permission must be obtained before attachments are made to Grant PUD owned poles. Attachments to Grant PUD owned poles shall be done strictly in accordance with Grant PUD specifications.

5.2.2 Underground Service Laterals

- A. In general, a building or other premises will be supplied through only one underground service lateral. Where the use of multiple service entrance conductors is necessary, the means and location of connection to the underground service lateral shall be determined by Grant PUD.
- B. The Customer is responsible for trench, conduit, sand bedding and backfill in accordance with Grant PUD specifications.
- C. Where conductors are buried directly in the earth, supplementary mechanical protection may be required by Grant PUD.
- D. Each underground installation shall be in accordance with specifications and drawings available from Grant PUD.

5.3 SERVICE ENTRANCE INSTALLATION AND EQUIPMENT

5.3.1 Responsibility of Customer/Grant PUD

All service entrance equipment, instrument transformer enclosures, meter enclosures, meter sockets, conduits and raceways are the responsibility of the Customer and shall be of a type approved by Grant PUD. The instrument transformers secondary circuit conductors will be supplied and installed by Grant PUD.

5.3.2 Wiring

The Customer shall provide and install all wiring between the Connection Point and the metering equipment with said installation subject to the provisions of Section 5.1.2. When the use of multiple conduits is necessary, the weatherheads shall be grouped such that none is more than 18 inches from the point of service attachment on the building. Underground wiring shall be buried enclosed in conduit (i.e. direct buried cable is not allowed).

5.3.3 Protective Devices

Suitable protective devices on the Customer's premises may be required whenever Grant PUD deems such installation necessary to protect its property or that of its other Customers.

Grant PUD may require installation of reduced voltage starting equipment by the Customer in cases where across the line motor starting would result in excessive voltage disturbances to other Customers or to Grant PUD's system. Grant PUD will furnish the Customer with written motor starting requirements based on the motor horsepower information given at the time of formal application for service. These requirements will be furnished only to the Customer. Construction and/or energization of Grant PUD Facilities to serve motor loads will not occur until the Customer acknowledges receipt of said requirements by signing and returning the motor starting requirements letter.

5.3.4 Protective Equipment on Motor Installations

On motor installations, adequate relays or other approved protective equipment to guard any and all motors against damage due to excessive under voltage and to protect three-phase motors against damage from single-phasing operation shall be the responsibility of the Customer. Three-phase motors equipped for restarting after a service interruption should be protected against any line condition resulting in single-phase service to the motors (single-phasing). Automatic restarting on 50 HP and larger motors must be approved by Grant PUD prior to installation.

It is recommended that three thermal over-current devices (for three-phase motors) and, in addition, dual element time delay fuses or circuit breakers of suitable rating be installed as minimum protection.

5.3.5 Service Connection

Service connections will be made only after it has been determined Grant PUD Construction Standards have been met and the Customer's electrical equipment/installation has been approved by a Washington State Electrical Inspector. Said equipment must display the State of Washington "Safe Wiring Decal", legibly filled out and readily accessible.

A False Call Fee will apply when a customer requests Grant PUD service and is not prepared when Grant PUD arrives on site at the requested timeframe, refer to fee schedule.

5.4 METER LOCATIONS

5.4.1 Placement of Meters

Grant PUD encourages placement of meters as close as possible to the designated Connection Point. In any event, meters or metering equipment shall be placed in locations that allow Grant

PUD free and safe access for installing, removing, testing, and reading. Metering equipment shall not be installed over open pits, moving machinery or hatchways. There shall be ample clearance from any such openings or hazardous locations and there shall be at least three (3) feet of unobstructed space between the nearest point of said metering equipment and any obstructions.

- A. Metering for residences shall be installed on the outside of the building, not enclosed, and readily accessible for meter reading and maintenance. (See Section 5.4.7)
- B. Metering equipment for commercial and industrial service shall be installed on the outside of the building in accordance with Section 5.4.1.A (above) except where prior approval of other locations has been granted by Grant PUD.
- C. Metering equipment for Irrigation service shall be outside of any buildings and may be installed on Grant PUD's transformer pole when such installation will provide improved access to the metering. For underground secondary service fed directly from a pole, meter location shall not exceed 20' distance from pole.

5.4.2 Meter Height Requirements

Meter bases or meter enclosures shall be located at such a height that the center of the meter when installed will not be more than six (6) feet, nor less than five (5) feet above finished grade, an accessible permanent platform or landing; except as follows:

- A. Meters for a special application may be installed at a height of less than five (5) feet in power rooms, if installed in a factory-built, metal cabinet approved by Grant PUD before fabrication.
- B. Outdoor factory-built multiple meter load centers for multifamily apartment buildings having seven (7) or more meters may be installed with up to four (4) vertical rows of meter sockets. (See Section 5.4.6) Mounting height shall be established by consulting with Grant PUD before proceeding with each such installation. The Customer shall plainly and permanently mark each meter location designating the portion of the building it serves before the service is connected.
- C. Meter height shall be measured from finished grade in meter pole applications.
- D. Meters on underground systems may be installed less than five (5) feet above finished grade at pad-mount transformer locations or in pedestals approved for the purpose.
- E. Where a written variance has been obtained from Grant PUD.

5.4.3 Line Side/Load Side Placement of Equipment

Metering equipment shall be installed on the line side of the main service switch or service panel, except on multiple meter installations where a main disconnecting means is required by Code. When meters are installed on the load side of the main disconnect as indicated above, they shall be installed on the line side of the individual subservice disconnect. The meters shall be connected directly to the main disconnect or through a bus gutter suitable for sealing. The Customer shall plainly and permanently mark each meter location, designating the portion of the building it serves before the service is connected.

5.4.4 Conditions Adversely Affecting Meters

Meters shall be installed in locations free from vibrations, condensation, or where live steam or hot liquids are used. They shall not be installed where such conditions exist which would adversely affect their operation. Metering equipment shall be located so it will not be in the path of water from eaves, rainspouts, or drains.

5.4.5 New Installation - Instrument Transformers

On new installations, meters used in connection with instrument transformers shall not be separated from the instrument transformer enclosures by a wall or partition. Secondary circuits of instrument transformers shall not be run in the same conduit or raceway with any other circuits. (See 5.5.5)

5.4.6 Placement of Meter Bases

There shall be a minimum of four (4) inches clearance between the meter base and service switch enclosure and/or any physical obstruction which might interfere with the installation of the meter or use of a test jack in the meter base.

Where a subdivision of the service requires the use of more than one meter, the meters shall be grouped and the space between sockets shall be not less than three (3) inches. On initial construction ganged meter troughs having two (2) or more meter sockets should be the bussed type.

5.4.7 Meter Violation

When any changes, alterations, additions or obstruction are made on the Customer's premises resulting in violation(s) of these meter requirements, the Customer shall correct the violation(s) at his expense or pay a monthly meter obstruction fee until said violation is corrected, refer to fee schedule.

5.5 METERING EQUIPMENT

5.5.1 Standards for Metering Equipment

Grant PUD establishes standards for metering equipment. The Customer's compliance with such standards shall be a condition of service.

5.5.2 Power Factor Metering

Grant PUD shall install reactive (Power Factor) metering on all Large Electric Service loads expected to operate such that the power factor will be below 95% lagging or leading. Nothing in the above shall preclude Grant PUD from installing reactive metering on any service, regardless of rate schedule or demand, when deemed necessary by Grant PUD. Meters for measurement of reactive power shall have registers for both leading and lagging power factors for the purpose of billing demand adjustments.

5.5.3 Pulse Metering Data Connection

Upon written request and execution of a letter agreement, Grant PUD will install and maintain Current Transformer (CT) metering, capable of KYZ output, as defined by Grant PUD Construction Standards for Industrial and Large General Customers subject to the following terms conditions:

- A. The Customer shall be responsible for paying in advance, all of Grant PUD's estimated costs for labor, materials, overheads and equipment needed for the installation and upon demand shall promptly reimburse Grant PUD for all repairs and maintenance costs incurred by it from time to time.
- B. Grant PUD will not synchronize the KYZ output to the meter demand timing.
- C. Grant PUD will retain ownership of all meters and equipment installed by it.
- D. The Customer shall be solely responsible for installation, operation, and maintenance of data logging equipment from Grant PUDs installed isolation relay(s). The Customer shall also provide voltage potential for the data logging equipment.
- E. The Customers communication equipment from the isolation relay(s) to the Customer's data logging equipment must be approved in advance by Grant PUD.
- F. Grant PUD shall have the right to work on the meter, including de-energization, without notice to or permission by the Customer. In the event the meter is removed and/or

replaced, Grant PUD may attempt, but will not guarantee, reconnection at the isolation relay(s).

- G. Grant PUD shall have no liability whatsoever or for any damages of any type to Customer resulting from or arising from the installation, operation or use of the KYZ output or from any malfunction thereof.

5.6 INTERCONNECTION OF CUSTOMER-OWNED NET METERING SYSTEMS

Grant PUD will allow net metering systems meeting Grant PUD's Construction Standards to interconnect on a first-come, first-served basis to Grant PUD's distribution system under the following terms and conditions:

5.6.1 Application, Fees and Agreement

Customer shall submit a Net Metering Application to Grant PUD prior to installing the generating facility along with an application fee, refer to fee schedule. Upon Grant PUD's approval of the Customer's Net Metering Application, Customer shall sign a Net Metering Interconnection Agreement. After Grant PUD's approval of the Net Metering Interconnection Agreement, Customer may at Customer's expense install the approved Net Metering System or modify as necessary or directed by Grant PUD Customer's generating facility in existence on Customer's property prior to the date these policies were enacted.

5.6.2 Certification of Completion

Upon the Customer's completion of the Net Metering System installation or modification, the Customer shall submit to Grant PUD a Certificate of Completion on a form provided by Grant PUD. Such form shall include evidence of inspection and approval of the Net Metering System by the State Electrical Inspector. Interconnection work to Grant PUD's distribution system will commence following receipt of the Certificate of Completion.

5.6.3 Unauthorized Connections

For the purposes of public and employee safety, any non-approved generation interconnections discovered will be immediately disconnected from Grant PUD's system.

5.6.4 Metering

Grant PUD shall install a kilowatt-hour meter, or meters as the installation may determine, capable of registering the bi-directional flow of electricity at a level of accuracy that meets all applicable standards, regulations and statutes. If Grant PUD requires separate metering to measure the energy produced by the generating facility, such equipment shall be installed at the Customer's expense.

5.6.5 Future Modification or Expansion

Prior to any future modification or expansion of the Customer-owned generating facility, the Customer will obtain Grant PUD approval. Grant PUD reserves the right to require the Customer, at the Customer's expense, to provide corrections or additions to existing electrical devices in the event of modification of government or industry regulations and standards.

5.6.6 Grant PUD System Capacity

The cumulative generating capacity of net metering systems shall be limited to 0.25% of Grant PUD's peak demand during 1996. Additionally, interconnection of Customer-owned generation to individual distribution feeders will be limited to 10% of the feeder's peak capacity. Additional generation interconnection to individual distribution feeders may be allowed beyond these stated limits at Grant PUD's discretion.

5.6.7 Customer Owned Protection

It is the responsibility of the Customer to protect their facilities, loads and equipment and comply with the requirements of all appropriate standards, codes, statutes and authorities. The Customer's Net Metering System must include, at the Customer's expense, all equipment necessary to meet applicable safety, power quality, and interconnection requirements established by the National Electrical Code (NEC), National Electrical Safety Code (NESC), the Institute of Electrical and Electronics Engineers (IEEE), Underwriters Laboratories (UL).

5.6.8 Interconnection Costs

Customer shall be responsible for all additional costs above and beyond the application fee, if any. Such costs will be based on actual costs, including overheads. For example additional costs may be incurred for transformers, production meters, and Grant PUD testing, qualification, and approval of non UL 1741 listed equipment.

6.0 METER READING, BILLING AND COLLECTING

6.1 METER READING

Meters will normally be read daily via advanced metering infrastructure.

If for any reason a reading cannot be obtained, the billing may be based on estimating energy use and demand, and subject to later correction.

Grant PUD's current technology has the ability to read, connect and disconnect meters remotely. The deployed technologies are Grant PUD's standards. If a Customer declines to adhere to Grant PUD's standards, refer to fee schedule and Opt-Out Agreement.

6.2 ADJUSTMENT OF BILLING ERRORS

Grant PUD may adjust any billing when it has been determined that an error in billing has been made and a correction is in order. Grant PUD may revise such bill on the basis of the best evidence available.

If the billing error is favorable to the Customer, Grant PUD will credit or refund the Customer's account for overcharges back to the date of when the billing error occurred and up to the date of discovery of the billing error.

If the billing error is unfavorable to the Customer, Grant PUD will charge the Customer's account for undercharges to the date of when the billing error occurred or six years (whichever lookback period is shorter) up to the date of discovery of the billing error. Grant PUD may establish an interest-free monthly payment arrangement for the undercharged amount for a Customer with a financial hardship as a result of the billing adjustment. The term of the payment arrangement term will not exceed the number of months of the lookback period.

6.3 BILLING PERIODS

The normal monthly billing period is 30 days. However, due to weekends and holidays, monthly billing periods may range from 26 to 34 days. Monthly charges for shorter or longer periods will be prorated on the basis that such fractional period bears to 30 days.

6.4 NON-METERED SERVICE

Non-metered service may be supplied when the connected load is known and average monthly energy consumption can be accurately calculated.

6.5 DETERMINATION OF DEMAND

Where Grant PUD rate is based on kW demand, the Metered/Billing Demand shall be calculated to the nearest thousandth (0.001) of a kW. Inaccurate demand readings caused by meter failure or loads with constantly changing demands may require the demand to be calculated by Grant PUD, taking into consideration installed capacity necessary to serve the load and abnormal effects on Grant PUD's system. Power factor metering data (if available) and/or the load history or load checks would also be used to compute the demand.

Grant PUD shall, if requested by Customer in advance, waive demand reads in one two-hour period for the sole purpose of Customer testing equipment. Grant PUD will not waive demand reads for this purpose more than one time in any 12-month period.

If monthly demand charges are based on Customer's highest demand, as provided by Grant PUD's then applicable rate schedule, a number of such recording periods equal to the first two hours following a system outage, not related to a failure in the Customer's Facility, shall be disregarded if noted by Grant PUD or if requested by the Customer.

6.6 PAYMENT

All monthly bills for service rendered and minimum charges are due and payable when rendered and become delinquent if not paid within 25 days.

6.7 RETURN CHECK FEE

A return check fee may be assessed to a Customer's account for which payment has been received by any check or legal tender which is subsequently returned to Grant PUD by the bank, refer to fee schedule.

6.8 PAYMENT OPTIONS

Customers may make payments to Grant PUD by cash, check, credit cards, debit cards, automated checking and savings account withdrawal and other Grant PUD approved electronic means.

6.9 BUDGETPAY

Rate Schedule 1 and 2 Customers may request to have BudgetPay. Monthly payments are due even if the account reflects a credit balance. BudgetPay accounts are subject to all other applicable articles of these policies. Copies of Grant PUD's level billing plan option is on file and is available upon request.

6.10 LATE PAYMENT CHARGES

If payment hasn't been received by Grant PUD on or before the due date, a late payment fee shall be assessed on the unpaid balances, refer to fee schedule.

6.11 ACCOUNT SERVICE CHARGE

During Grant PUD's normal business hours, an account service fee will be made for a service transfer or a turn on, refer to fee schedule.

6.12 AFTER-HOURS FEE

Any Customer requested service requiring Call Center service call-out (excluding power outages) outside of regular Call Center hours (visit www.grantpud.org for listed hours) will incur an after-hours fee. Refer to fee schedule.

Any Customer requested service requiring an on-site service call-out (excluding power outage response) outside of normal work hours (6:00am and 4:00pm Monday – Thursday), an after-hours fee will be applied. Exceptions may apply on Friday's if service crews are scheduled to work. Refer to fee schedule.

6.13 DEPOSITS

Deposits may be required for Customers. If the Customer fails to comply with or make any of

the payments required by Grant PUD, or fails to maintain other security in lieu of a cash deposit the Customer will not be provided service or may be disconnected in accordance with Grant PUD's disconnect for non-payment policy. The full amount of the deposit, plus the disconnect for non-payment fee, will be required prior to turning the service back on.

6.13.1 Current Credit Rating

Credit activity for every Customer account is rated via a point system. Prior to any deduction, each account has a Current Credit Rating of 1,000. Credit activity at any service under the account may affect the credit point total.

Deductions will remain in effect for 12 months from the date incurred for Domestic Services and 18 months for all other services unless otherwise noted.

Customers will return to a credit rating score of 1,000 when all adverse credit activity deductions have expired according to the above schedule.

6.13.2 Interest on Deposits

Deposits will earn interest and will be calculated and accrued monthly. The applicable interest rate applied is available upon request.

6.14 NEW OR ADDITIONAL DEPOSIT REQUIREMENTS

Grant PUD may require a new or additional deposit for Customers whose service(s) experience significant electrical load changes or develop credit problems.

ADEQUATE ASSURANCE OF FUTURE PAYMENT

When a Customer files a bankruptcy petition, the Customer's existing service(s) will be closed and new service(s) established. If any of the Customer's accounts are delinquent at the time of such filing, Grant PUD may require a new or additional deposit or other adequate assurance of future payment pursuant to 11 USC Section 366. Payment of the deposit or other assurance of future payment will be required within twenty (20) days of the date of the order for relief as provided in 11 USC Section 366.

6.15 TERMINATION OF SERVICE

Upon termination of service, Grant PUD will refund to the Customer the amount currently on deposit plus accumulated interest after deducting all amounts due Grant PUD.

6.16 DELINQUENCY-DISCONTINUANCE OF SERVICE

6.16.1 Right to Disconnect

The right to discontinue service when delinquent may be exercised whenever and as often as delinquency shall occur and neither delay nor omission on the part of Grant PUD to enforce this rule at any one or more times shall be deemed as a waiver of its rights to enforce the same at any time, so long as the delinquency continues.

Except where prohibited by law, Grant PUD reserves the right to refuse, to limit or to disconnect service to any Customer having a delinquent balance and may transfer the delinquent balance to the Customer's active account for collection purposes.

The Customer Service Representative may make payment arrangements with the Customer for a payment schedule for the bill. However, Grant PUD shall not be required to enter into a payment schedule with a Customer who has not fully and satisfactorily complied with the terms of a previous payment schedule.

6.16.2 Due Process

Except in the case of emergencies and exceptional circumstances, as determined by Grant PUD, notice will be given to the Customer or occupant warning of discontinuance of service to allow the opportunity for reconciliation of an account and cancel a disconnect for non-payment.

6.17 DISCONNECT FOR NON-PAYMENT

This section will apply to all disconnects for non-payment except as otherwise specified.

6.17.1 Disconnect Fee

Whenever service has been disconnected for non-payment or fraudulent use, a disconnect fee will be charged to the account, refer to fee schedule. The disconnect fee may be waived for Customers who under Washington law qualify for medical or public assistance and when reconnection payment is funded by a private, non-profit funding agency subject to 501(C)(3) tax exemption.

For re-connection outside of Grant PUD's normal business hours for services that have been disconnected for non-payment refer to Section 6.13.

6.17.2 Moratorium

Grant PUD's disconnect for non-payment policy is set forth in Section 6.18 and shall be subject to the requirements of RCW 54.16.285.

6.18 LANDLORD/TENANT ARRANGEMENTS

Landlords of rental residences may arrange with Grant PUD for service to the designated rental to remain energized and to be transferred to the landlord when tenants request termination of service by signing up for Landlord Service. The landlord shall be responsible for any basic charges and energy consumption prior to the transfer of the service to a new tenant.

In most cases where the Landlord is the Customer and requests termination of service to a rental residence or fails to pay for such service, Grant PUD may notify the tenant by hanging a door tag stating that the tenant has five (5) days to put the account into their name and the Landlord will be assessed a fee, refer to fee schedule. Requests for termination of utility service by a landlord, for the purpose of evicting a tenant, is prohibited by RCW 59.18.300.

6.19 ELIGIBILITY FOR SPECIAL LOW INCOME RATE DISCOUNTS

Grant PUD offers a Low-Income Senior Citizen rate discount and a Low-Income Disabled rate discount for qualifying residential Customers as defined in Rate Schedule 1.

To be eligible for either of these rate discounts, the total household income including Customer's spouse or co-tenant(s) must be equal to or less than 200% of the poverty guidelines as updated periodically in the Federal Register by the U.S. Department of Health and Human Services under the authority of 42 U.S.C. 9902(2).

Eligibility requirements for low-income rate discounts are as follows:

- A. **LOW-INCOME SENIOR CITIZEN DISCOUNT:** In addition to meeting the household income eligibility criteria as stated above, Customer must be 62 years or older prior to or

during the month in which the discount will be applied.

- B. **LOW-INCOME DISABLED DISCOUNT:** In addition to meeting the household income eligibility criteria as stated above, Customer must obtain certification from a Physician or Mental Health Professional that Customer meets the disability criteria defined in RCW 74.18.020, RCW 71A.10.020 or RCW 46.16.381. Such certification must be on Grant PUD's approved form.

Only one low-income rate discount shall be applied to Customer's account regardless of whether they qualify for both rate discounts. Rate discounts will be applied only to the residential service serving as the Customer's primary dwelling. Eligibility will be verified in writing by either Grant PUD staff, Department of Social and Human Services or other Grant PUD-approved assistance agency.

Changes in the customers income or location will require reverification of the eligibility requirements. The low-income discount rate shall expire, three (3) years from the date the discount was applied but may be allowed to continue for additional three (3) year periods provided the customer provides reverification of the eligibility requirements. Customers unable to verify eligibility requirements within 30 days of Grant PUD's request or upon expiration of the discount will be removed from the rate discount program.

Grant PUD reserves the right to schedule a no cost home energy assessment at the premise where the discount is applied. If the customer refuses the home energy assessment, the customer discount will be removed within 30 days upon failure to allow the assessment.

6.20 NET METERING BILLING

Pursuant to RCW 80.60.030, Customers participating in Grant PUD's Net Metering Program shall be billed and credited in accordance with the following:

- A. Grant PUD shall measure the net electricity produced or consumed by the Customer during each billing period, in accordance with normal metering practices.
- B. If the electricity supplied by Grant PUD exceeds the electricity generated by the Customer and fed back to Grant PUD during the billing period, or any portion thereof, then the Customer shall be billed for the net electricity supplied by Grant PUD together with the appropriate Basic charge paid by the Customers in the same rate class.
- C. If the electricity generated by the Customer and distributed back to Grant PUD during the billing period, or any portion thereof, exceeds the electricity supplied by Grant PUD, then the Customer shall be:
1. billed for the appropriate Basic charge or minimum charge as other customers in the same rate class for that billing period; and
 2. credited for the net excess kilowatt-hours generated during the billing period, with this kilowatt-hour credit appearing on Customer's bill for the following billing period
- D. On March 31st of each calendar year, any remaining unused kilowatt-hour credit accumulated by the Customer during the previous year shall be granted to Grant PUD, without any compensation to the Customer.
- E. Customer shall pay any amount owing for electric service provided by Grant PUD in accordance with applicable rates and policies. Nothing in this Section shall limit Grant PUD's rights under applicable Rate Schedules, City Ordinances, Customer Service Policies, and General Provisions.

6.21 RENEWABLE ENERGY SYSTEM COST RECOVERY

Customers participating in Grant PUD's Net Metering Program may be eligible each fiscal year for an investment recovery incentive for each kilowatt-hour generated by the Customer provided Customer complies with RCW 82.16.120.

7.0 STREET LIGHTING SERVICE

7.1 AVAILABILITY

Street Lighting Service will be made available in accordance with Rate Schedule 6, Street Lighting Service and the terms and conditions of these Customer Service Policies, as they now exist or may be hereafter amended.

7.2 SPECIFICATIONS

For qualified applicants, Grant PUD will provide and install a system of unmetered street lighting facilities for dusk to dawn operation. Conventional Street Lighting consists of overhead or underground conductors with mast arms and luminaries mounted on wood, concrete, or metal poles. Decorative Street Lighting units consist of a decorative post and two decorative arms, each with a single acorn globe. Modified arm units consist of two decorative arms, each with a single acorn globe, modified to fit on existing street light standards. When streetlights are installed, the Customer shall pay a monthly charge based on the facilities provided as specified in Rate Schedule 6.

7.3 LINE EXTENSION POLICY - STREET LIGHTS

Grant PUD will construct and supply the necessary lighting equipment to include single-phase transformers and secondary voltage facilities to effect delivery of street lighting service upon written request and authorization from qualifying customers. Primary facilities that do not qualify as an Area Feeder and are installed by Grant PUD to provide power for the aforementioned secondary facilities, shall be provided in accordance with Line Extension Policy, Section 4.0 and the appropriate Line Extension Fee paid by the Customer.

7.3.1 Underground Service to Street Lights

Underground Service will be provided where practicable. The Customer is responsible for trenching, conduit, sand bedding and backfilling. For decorative street lighting, the Customer shall also supply and install any mounting bases required. If Grant PUD provides the trenching, the full cost will be charged to the Customer at the time of construction.

7.4 TERMINATION OF SERVICE

The Customer shall continue to pay for service to all types of streetlights until such time as a written request for termination, signed by an authorized individual, is received by Grant PUD. Upon termination the Customer shall pay a Termination Charge reduced by; (a) 20% for Conventional Street Lighting; or (b) 5% for Decorative Street Lighting, for each full twelve (12) month period since installation of the facilities.

7.5 CONTINUITY OF SERVICE

Grant PUD does not guarantee continuity of service and shall not be liable for any interruption of street light service or damage resulting therefrom which is caused by vandalism, normal equipment failure, accidents, acts of God, unavailability of power supply to meet Grant PUD's load requirements, the necessity for making repairs or changes in Grant PUD's equipment and facilities, or by any other cause reasonably beyond Grant PUD's control.

Grant PUD has determined it is not cost effective or practicable to patrol at night to find streetlights that are not functioning properly and/or are damaged. Because of this Grant PUD depends on the Customer and the general public to notify Grant PUD that streetlights are not functioning properly

and/or are damaged. Grant PUD will, within a reasonable time after notification, make necessary repairs to restore street lighting service.

8.0 LARGE POWER CUSTOMER ELECTRIC SERVICE ABOVE 500 KW/KVA

Customers with loads in excess of 500 kW/kVA are considered Large Power Customers and can take Electric Service from Grant County PUD under the following Rate Schedules:

Rate Schedule 7	Large General Service
Rate Schedule 14	Industrial Service
Rate Schedule 15	Large Industrial Service
Rate Schedule 16	Agricultural Food Processing Service
Rate Schedule 17-B	Evolving Industry Service
Rate Schedule 85	Agricultural Food Processing Boiler Service
Rate Schedule 94	New Large Load Service

Rate Schedules can be found at grantpud.org.

A Large Power Customer’s presence on Grant PUD’s Electric System has material impacts on it. In addition to design considerations for deliverability of large amounts of Electric Power, there are also rate impacts caused by the magnitude of capital and incremental O&M required to connect and serve Large Power Customers. This Section 8 describes the policies that shall be used to implement the Large Power Customer Rate Schedules including mitigating the shifting of long- term costs to other Rate Schedules.

8.1 NEW LARGE ELECTRIC SERVICE

Those desiring Electric Service in excess of 500 kW/kVA on Grant PUD’s Electric System must provide Grant PUD a completed Large Electric Service Application along with a nonrefundable application fee (see Grant PUD’s Fee Schedule). Applications for non-Evolving Industry uses shall be placed into the “Large Electric Service Queue” and processed prior to the Evolving Industry Queue.

Applications submitted for Evolving Industry uses as defined per Rate Schedule 17, shall be placed into a separate queue (Evolving Industry Queue) on a first-come-first-served basis. The Evolving Industry Queue is independent of the Large Electric Service Queue for all other Rate Schedules. The Evolving Industry queue shall be processed after the Large Electric Service Queue is processed, unless the Evolving Industry Customer’s requests coincides with a Large Electric Service Queue expansion or study.

8.2 CUSTOMER RESPONSIBILITIES

The Customer shall work with Grant PUD staff to identify Facilities Customer may construct for itself or Grant PUD for the delivery of Electric Power. Grant PUD requires the Customer comply with all applicable Grant PUD standards, laws, codes and regulations when constructing Facilities and allow Grant PUD to approve and inspect Metering Facilities and the first Customer Facility protective device beyond the Demarcation Point.

The Customer shall also provide the appropriate transfer(s) of property and the appropriate rights and easements to Grant PUD to allow it to construct and operate Grant PUD Facilities required to provide Electric Service to the Customer.

8.3 FACILITIES

Grant PUD will generally supply Large Electric Service requests of 2000 kW/kVA and below at three phase secondary voltage. Grant PUD's standard secondary nominal voltages are 120/208V and 277/480V. Industrial customers requesting Electrical Service above 2000 kW/kVA shall be provided primary voltage metered service at nominal 13.2kV three phase.

Unless otherwise agreed to in writing between Grant PUD and the Customer, Grant PUD will establish the Demarcation Point.

8.4 CUSTOMER CONTRIBUTION FOR CONNECTION

Grant PUD shall perform the necessary studies to determine what Facilities need to be constructed, reconfigured, upgraded or refurbished as the Large Electric Service Application moves through the queue. Upon completion of the studies the Customer shall be briefed on the results of such studies and the amount of a Customer Contribution shall be estimated.

Assuming the Customer wishes to continue, it shall execute an agreement that includes the details for the Facilities Plan, provisional power, design, and proposed schedule along with the Customer Contribution amount ("Facilities Agreement"). The Customer Contribution is calculated to prevent the shifting of long-term costs within a rate class or group or to other rate classes or groups.

The Customer Contribution is calculated by Grant PUD staff. Customers requiring 20 MVA or less use a prescriptive method to calculate the Customer Contribution. Customers requiring more than 20 MVA of new service require more detailed study.

Should the Customer cancel the project, a portion or all of the Customer Contribution may be returned to the Customer provided that the refunding does not, in Grant PUD's sole discretion, shift costs to others.

8.5 REDUNDANT FACILITIES

Prudent utility practice ensures that Facilities are adequate to provide Electric Service to Customers safely, reliably and cost effectively but does not provide redundancy to any particular Customer. If the Customer has a need for a greater level of redundancy than provided by Grant PUD, it can request such redundancy for its Electric Service. Any Facilities provided by Grant PUD to increase redundancy shall in no way modify or alter Grant PUD's obligations or limitations of liability provided in Section 2.

Because redundant facilities are by definition unloaded and available for use at any time, the Customer Contribution required to avoid shifting costs to others may be significant. The Facilities Agreement associated with redundant Electric Service shall specify the required Customer Contribution. If Grant PUD, in its sole discretion, identifies that there are on-going operating costs that need to be recovered related to the redundant unloaded facilities, it shall work with the Customer to identify such costs and establish a Rate Schedule or execute contracts to provide payment to prevent shifting long-term costs to others.

Redundant Electric Service Facilities fall into three broad categories as described below.

8.5.1 Redundant Distribution

Includes the provision of a second distribution feeder to serve the Customer's Facilities. Redundant distribution may or may not come from two different substations.

8.5.2 Redundant Transformer

Provides additional substation capacity through additional unloaded equipment such that the

failure of one transformer will not cause the Customer an Electric Service interruption. Redundant transformers may or may not be in the same substation.

8.5.3 Redundant Transmission

Consists of an alternate source of transmission connected to a substation or substations where the alternate source comes from a different transmission yard breaker.

9.0 EVOLVING INDUSTRY

To retail Customers whose load activity and/or industry meets the requirements of an Evolving Industry (EI Criteria).

9.1 RISK CONSIDERATIONS FOR INCLUSION

9.1.1 Concentration Risk

Potential for significant load concentration within Grant PUD's service territory resulting in a meaningful aggregate impact and corresponding future risk to Grant's revenue stream. Evaluation would begin to occur when industry concentration of existing and service request queue customer loads exceeds 5% of Grant PUD's total load and service request queue.

9.1.2 Business Risk

The risk of stranding Grant PUD assets constructed to serve a Customer or causing unrecoverable costs due to cessation or significant reduction of electric consumption arising from an Industry's general business environment.

9.1.3 Regulatory Risk

Risk of detrimental changes to regulation with the potential to render the industry inviable within a foreseeable time horizon.

9.2 PERIODIC REVIEW BY ASSESSMENT TEAM

At least every two years a team will review which Customers, customer types, or uses of electricity are to be included in the Evolving Industry Rate Class. The Evolving Industries Assessment Team shall use prudent business and utility practices to establish criteria and classify load activities and industries as belonging to the Evolving Industry Rate Class.

The Evolving Industry Assessment Team shall include Grant PUD staff representing the following departments and sections (or their successors) of Grant PUD:

- A. Large Power Solutions
- B. Customer Solutions
- C. Engineering
- D. Rates & Pricing
- E. Finance/Accounting

The Evolving Industry Assessment Team shall be selected by the PUD's executive management.

Grant PUD posts the list of Industries or Identified Uses that qualify for Rate Schedule 17 on its website at www.grantpud.org.

The Evolving Industry Assessment Team shall review and value the costs and risks associated with serving Evolving Industries and provide any recommended changes to the Commission. Risk elements considered include, but are not limited to, future transmission requirements, impact to Grant PUD equipment, increased power supply cost risk, and potential stranded asset risk.

9.3 INCLUSION IN THE EVOLVING INDUSTRY RATE CLASS

A load activity and/or industry shall be included in the Evolving Industry Rate Class if it meets the

criterion of section 9.1.1., Concentration Risk, and also meets the criteria of either section 9.1.2. or section 9.1.3., Business Risk and Regulatory Risk, respectively.

A load activity and/or industry shall be removed from the Evolving Industry Rate Class if and only if it no longer meets the criteria of 9.1.2. and 9.1.3.

9.4 RATE 17 DESIGN

Rate Schedule 17 is designed to consider risks associated with the Evolving Industry class in order to minimize cost shifting to other Customer classes.

Rate 17 includes factors common to any Customer class such as allocated operating and capital costs, a risk premium, and any Commission policy direction applicable to Rate 17 that may include specific additional charges or adders. The risk premium portion of the rate may include but not be limited to risks such as future transmission / infrastructure requirements, loading and utilization of Grant PUD equipment, potential increase or additional volatility in power supply cost, risk of under or unutilized (stranded) assets, and future revenue volatility or loss.

The risk component of Rate Schedule 17 will be reviewed at least every two years and may be adjusted up or down by the Commission in accordance with changes to the risk profile.

9.5 COMMISSION REPORTING

When the Evolving Industry Assessment Team determines that an industry meets the Rate 17 criteria, staff will provide a memo for Commission review and action. Likewise, when staff determines that an industry no longer meets the criteria of Rate 17, staff will provide notice to the Commission for Commission review and action. The memos are part of the public packet posted to Grant PUD's website. Customers and stakeholders may comment to the Commission in public session regarding the change.

The Evolving Industry Assessment Team will also at least every two years update the Commission, independent of whether or not any changes are being made to the Evolving Industry Rate class, with a summary of the evaluation of the risk premium of Rate Schedule 17. Based upon this information the Commission will consider the need for rate changes and may modify Rate 17.

9.6 APPLICATION AND QUEUE

Customers desiring to apply for new or increased service shall apply as described in Section 2.7 and Section 8.1 of this Customer Service Policy.

9.7 ATTESTATIONS

Any new or existing customers placed under the Evolving Industry Rate Schedule 17 shall provide an attestation demonstrating they do not qualify or meet the criteria to be served under this rate schedule as a condition of Grant PUD to provide Electric Service under a different rate schedule.

Once established, if a Customer changes its business such that it no longer meets the Rate Schedule 17 Evolving Industry criteria, the customer may be required to affirm their attestation that they are not participating in an Evolving Industry and no load on its Premises is participating in any Evolving Industry. If a customer changes its business such that it does meet the Rate Schedule 17 Evolving Industry criteria the customer is required to inform the PUD of the change in status. Failure to inform the PUD may result in penalties as described in section 9.8.

9.8 LOAD SPLITTING AND METERING

If residential Customers on Rate Schedule 1 are participating in an Evolving Industry or plan to

participate in an Evolving Industry, the entire load at that Premises will be billed in accordance with Rate Schedule 17. Grant PUD, in its sole discretion, may allow the Customer to split the loads provided however, the customer is required to reimburse Grant PUD for all costs associated with providing the additional metering.

If a Large Power Customer has a portion of their load that qualifies for Rate Schedule 17, Grant PUD, in its sole discretion, may allow the Customer to split the loads provided however, the customer is required to reimburse Grant PUD for all costs associated with providing the additional metering.

9.9 DETECTION AND ENFORCEMENT

The PUD shall monitor Customers in the normal course of business just as it does for diversion of service and unsafe conditions. Grant PUD will use various means it has available to collect information and make observations about its Customers to ensure each Customer is on the correct Rate Schedule.

Industries tend to have similar usage patterns which may identify certain Premises where a change of Rate Schedules would be appropriate. Grant PUD shall reconfirm the self-attestation made by the Customer.

Grant PUD will make reasonable efforts to contact the Customer and discuss Grant PUD's findings and shall ask the Customer for assurances that they are not participating in the Evolving Industry. Should the Customer refuse to provide adequate assurances that it is not participating in an Evolving Industry, Grant PUD shall assume the Customer is participating in the Evolving Industry and convert the Customer to Rate Schedule 17 until the Customer ceases to participate in the Evolving Industry or demonstrates that it is not.

9.10 PENALTIES

Grant PUD has the authority to enforce its Rate Schedules and intends to do so to the full extent allowed by the law. Customers found to have knowingly deceived and/or found to have been charged under an incorrect Rate Schedule based on Customer representations will be processed the same way as diversion in Section 2.15 of this Customer Service Policy and subject to penalties. Grant PUD reserves the option to assess damages from the date Grant PUD estimates the customer's Rate Schedule should have changed, as allowed in Section 2.1.2, and pursue any uncollected applicable charges.

9.11 INFORMAL CONFERENCE / HEARINGS

Customers who have a dispute regarding the application of this Customer Service Policy may request an informal conference as described in Section 2.16 herein. If the Customer wishes to pursue the matter further, Section 2.16 also describes how to request a hearing.

10.0 REVISIONS

Section	Description	Revised	Resolution
1.0	PREAMBLE	04/23/19	8916
1.1	DEFINITION OF TERMS	04/23/19	8916
2.0	GENERAL POLICIES	08/09/82	4150
2.1.1	Metering Point	03/20/06	7952
2.1.2	Determination of Applicability	09/26/11	8575
2.2	RATE SCHEDULES	11/12/13	8696
2.2.1	Rate Schedule Exceptions	08/14/18	8890
2.3	NEW LOADS	12/22/03	7671
2.4	EXCLUSIVE SOURCE AND RESALE	11/01/04	7746
2.5	GRANT PUD'S OBLIGATIONS	06/23/98	7223
2.5.1	Limitations of Damages		
2.6	CUSTOMER'S OBLIGATIONS	06/23/98	7223
2.6.1	Increased Load	08/14/18	8890
2.6.2	Balancing of Load	06/23/98	7223
2.6.3	Total Harmonic Distortion (THD)	11/01/04	7746
2.6.4	Surge Protection	10/27/08	8296
2.7	APPLICATION FOR SERVICE	06/23/98	7223
2.8	DISCONNECTING SERVICES	06/23/98	7223
2.9	LIFE SUPPORT SYSTEMS	04/16/85	
2.9.1	Customer Obligations	11/01/04	7746
2.10	DAMAGE TO GRANT PUD FACILITIES	06/23/98	7223
2.11	DISCLOSURE OF PUBLIC RECORDS	11/19/01	7491
2.12	SERVICE OUTSIDE GRANT COUNTY	02/10/92	
2.13	UNDERGROUND FACILITIES	05/23/05	7821
2.14	REVENUE PROTECTION AND POWER DIVERSION	10/24/17	8859
2.15	INFORMAL CONFERENCE / HEARINGS	06/23/98	7223
3.0	CONSERVATION	06/23/98	7223

Section	Description	Revised	Resolution
3.1	RESIDENTIAL, COMMERCIAL, INDUSTRIAL AND IRRIGATION ASSISTANCE	11/19/01	7491
4.0	LINE EXTENSION POLICY FOR CUSTOMER SERVICES UNDER 500 KW	08/14/18	8890
4.1	OVERHEAD LINE EXTENSIONS	09/29/97	7145
4.2	UNDERGROUND LINE EXTENSIONS	11/19/01	7491
4.3	TYPES OF SERVICE	11/28/05	7896
4.3.1	Permanent Service	09/29/97	7145
4.3.2	Non-Permanent Service	05/23/05	7821
4.3.3	Construction Temporary Service	08/14/18	8890
4.4	SERVICE REQUIREMENTS BY RATE CLASS	10/24/17	8859
4.5	CALCULATION OF CHARGES	09/29/97	7145
4.5.1	Line Extension Fees	09/29/97	7145
4.5.2	Line Extension Fee Payments	09/29/97	7145
4.6	MODIFICATION OF FACILITIES	09/29/97	7145
4.7	REBUILDING EXISTING LINES	09/29/97	7145
4.8	TRANSMISSION FACILITIES	09/29/97	7145
4.9	SUBSTATIONS	09/29/97	7145
4.10	DISTRIBUTION POWER LINES	09/29/97	7145
4.10.1	Area Feeder Lines	09/29/97	7145
4.10.2	Distribution Power Lines That Are Not Area Feeders	09/29/97	7145
4.11	EXTENSIONS TO RESIDENTIAL/COMMERCIAL SUBDIVISIONS	01/03/11	8527
4.11.1	Approved Subdivisions		
4.11.2	Services within a Subdivision		
4.12	MANUFACTURED HOME / MOBILE HOME PARKS		
4.13	UNUSED IRRIGATION SERVICE FACILITIES		
5.0	SERVICE AND METER REGULATIONS		
5.1.1	Determination of Availability	11/28/05	7896
5.1.2	Compliance with Regulations and Codes		
5.1.3	Access to and Care of Grant PUD Property		
5.1.4	Customer Responsibility		

Section	Description	Revised	Resolution
5.1.5	Separate Services		
5.1.6	Backup and Maintenance Power		
5.1.7	Station Service - Customer Owned		
5.2	SERVICE LATERAL AND POINT OF CONNECTION	06/23/98	7223
5.2.1	Overhead Service Laterals	06/23/98	7223
5.2.2	Underground Service Laterals	12/22/03	7671
5.3	SERVICE ENTRANCE INSTALLATION AND EQUIPMENT		
5.3.1	Responsibility of Customer/Grant PUD	06/23/98	7223
5.3.2	Wiring		
5.3.3	Protective Devices	06/23/98	7223
5.3.4	Protective Equipment on Motor Installations		
5.3.5	Service Connection		
5.4	METER LOCATIONS		
5.4.1	Placement of Meters		
5.4.2	Meter Height Requirements		
5.4.3	Line Side/Load Side Placement of Equipment		
5.4.4	Conditions Adversely Affecting Meters	12/05/94	6798
5.4.5	New Installation - Instrument Transformers	10/24/17	8859
5.4.6	Placement of Meter Bases	11/19/01	7491
5.4.7	Meter Violation	11/28/05	7896
5.5	METERING EQUIPMENT	05/08/06	7974
5.5.1	Standards for Metering Equipment		
5.5.2	Power Factor Metering	02/26/07	8098
5.5.3	Pulse Metering Data Connection	02/26/07	8098
5.6	INTERCONNECTION OF CUSTOMER-OWNED NET METERING SYSTEMS	10/24/17	8859
5.6.1	Application, Fees and Agreement	02/26/07	8098
5.6.2	Certification of Completion	02/26/07	8098
5.6.3	Unauthorized Connections	02/26/07	8098
5.6.4	Metering	02/26/07	8098

Section	Description	Revised	Resolution
5.6.5	Future Modification or Expansion	02/26/07	8098
5.6.6	Grant PUD System Capacity	02/26/07	8098
5.6.7	Customer Owned Protection	05/28/13	8677
5.6.8	Interconnection Costs	08/30/99	7308
6.0	METER READING, BILLING AND COLLECTING	08/30/99	7308
6.1	METER READING	08/30/99	7308
6.2	ADJUSTMENT OF BILLING ERRORS	08/30/99	7308
6.3	BILLING PERIODS	11/01/04	7746
6.4	NON-METERED SERVICE	05/24/04	7710
6.5	DETERMINATION OF DEMAND	10/24/17	8859
6.6	PAYMENT	05/28/13	8677
6.7	RETURN CHECK FEE	05/28/13	8677
6.8	PAYMENT OPTIONS	10/24/17	8859
6.9	BUDGETPAY	10/24/17	8859
6.10	LATE PAYMENT CHARGES	10/24/17	8859
6.11	ACCOUNT SERVICE CHARGE	01/04/10	8446
6.12	AFTER-HOURS FEE	06/04/07	8130
6.13	DEPOSITS	04/08/14	8720
6.13.1	Current Credit Rating	04/08/14	8720
6.13.2	Interest on Deposits	04/08/14	8720
6.14	NEW OR ADDITIONAL DEPOSIT REQUIREMENTS	04/08/14	8720
6.15	TERMINATION OF SERVICE	04/08/14	8720
6.16	DELINQUENCY-DISCONTINUANCE OF SERVICE	04/08/14	8720
6.16.1	Right to Disconnect	04/08/14	8720
6.16.2	Due Process	10/24/17	8859
6.17	DISCONNECT FOR NON-PAYMENT	11/19/01	7491
6.17.1	Disconnect Fee	10/24/17	8859
6.17.2	Moratorium	02/11/08	8203
6.18	LANDLORD/TENANT ARRANGEMENTS	02/26/07	8098

Section	Description	Revised	Resolution
6.19	ELIGIBILITY FOR SPECIAL LOW INCOME RATE DISCOUNTS	08/26/14	8743
6.20	NET METERING BILLING	02/10/92	6501
6.21	RENEWABLE ENERGY SYSTEM COST RECOVERY	02/10/92	6501
7.0	STREET LIGHTING SERVICE	12/28/87	5674
7.1	AVAILABILITY	02/10/92	6501
7.2	SPECIFICATIONS	02/10/92	6501
7.3	LINE EXTENSION POLICY - STREET LIGHTS	12/28/87	5674
7.3.1	Underground Service to Street Lights		
7.4	TERMINATION OF SERVICE		
7.5	CONTINUITY OF SERVICE		
8.0	LARGE POWER CUSTOMER ELECTRIC SERVICE ABOVE 500 KW/KVA	04/23/19	8916
8.1	NEW LARGE ELECTRIC SERVICE	04/23/19	8916
8.2	CUSTOMER RESPONSIBILITIES	04/23/19	8916
8.3	FACILITIES	04/23/19	8916
8.4	CUSTOMER CONTRIBUTION FOR CONNECTION	04/23/19	8916
8.5	REDUNDANT FACILITIES	04/23/19	8916
8.5.1	Redundant Distribution	04/23/19	8916
8.5.2	Redundant Transformer	04/23/19	8916
8.5.3	Redundant Transmission	04/23/19	8916
9.0	EVOLVING INDUSTRY	03/26/19	8915
9.1	RISK CONSIDERATIONS FOR INCLUSION	03/26/19	8915
9.1.1	Concentration Risk	03/26/19	8915
9.1.2	Business Risk	03/26/19	8915
9.1.3	Regulatory Risk	03/26/19	8915
9.2	PERIODIC REVIEW BY ASSESSMENT TEAM	03/26/19	8915
9.3	EVOLVING INDUSTRY ENTRY AND EXIT CRITERIA		
9.4	RATE 17 DESIGN	03/26/19	8915
9.5	COMMISSION REPORTING	03/26/19	8915
9.6	APPLICATION AND QUEUE	03/26/19	8915

Section	Description	Revised	Resolution
9.7	ATTESTATIONS	03/26/19	8915
9.8	LOAD SPLITTING AND METERING	03/26/19	8915
9.9	DETECTION AND ENFORCEMENT	03/26/19	8915
9.10	PENALTIES	03/26/19	8915
9.11	INFORMAL CONFERENCE / HEARINGS	03/26/19	8915
10.0	REVISIONS	04/01/23	[PENDING]